

Natural Environment Referral Response - Riparian

Application Number:	DA2022/0581
---------------------	-------------

Date:	14/07/2022
То:	Adam Susko
	Lot 2 DP 1275526 , 1 Golf Avenue MONA VALE NSW 2103 Lot 249 DP 752046 (SPL 76319) Lot 323 DP 824000 (Crown Lease 200108) , 3 Golf Avenue MONA VALE NSW 2103 Lot 249 DP 752046 (SPL 76319) Lot 323 DP 824000 (Crown Lease 200108) , 3 Golf Avenue MONA VALE NSW 2103

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The development application is for alterations and additions to commercial development (Mona Vale Golf Club), and associated works.

This application has been assessed against relevant legislation and policy relating to waterways, riparian areas, and groundwater.

The development must not significantly impact on the biophysical, hydrological or ecological integrity of the receiving waters, or the quantity and quality of surface and ground water flows that it receives.

Sediment and erosion controls must be installed prior to any disturbance of soil on site and maintained until all work is complete and groundcover re-established.

The proposal is therefore supported.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the

DA2022/0581 Page 1 of 2



Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prepared by <INSERT> prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.

DA2022/0581 Page 2 of 2