

Building Assessment Referral Response

Application Number:	Mod2024/0550
	Modification of Development Consent DA2018/1654 granted for Demolition works and Construction of a new aged care facility including underground parking
Date:	01/11/2024
То:	Kye Miles
Land to be developed (Address):	Lot 3 DP 805710 , 181 Forest Way BELROSE NSW 2085

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- · Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respect to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development.

<u>Note:</u> The proposed development may not comply with some requirements of the BCA. Issues such as these however may be determined at Construction Certificate stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

National Construction Code (BCA) upgrade requirements and Fire Safety upgrade

The National Construction Code works as detailed and recommended in the BCA Assessment Report prepared by Steve Watson & Partners, dated 28 March 2024, Report Ref No. 2023/2268 R1.0, are to be considered as part of the assessment of the Construction Certificate.

Details demonstrating compliance are to be provided to the Certifier prior to the issue of the Construction Certificate.

MOD2024/0550 Page 1 of 2



Reason: To ensure adequate provision is made for Health, Amenity, Access & Fire Safety for building occupant health & safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate. Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Parts 10, 11 & 12 of the Environmental Planning and Assessment (Development Certification and Fire Safety) Regulation 2021.

MOD2024/0550 Page 2 of 2