

EXCEPT ONLY

Only information that is relevant to the site has been provided



Northern Beaches Council Renewable Energy Options Study Final Report

Date:

31 August 2017



2.3 Aquatic Centre, Boy Charlton, Manly

2.3.1 Summary

Due to not having a full year interval data and the delayed starting of the cogeneration unit the load profile for March 2017 has been used for modelling as a standard month's load across the year.

Within this month there is a variance of 100kW up to 180 kW from day to day, and modelling takes this potential for high variance into account.

Peak demand savings from solar PV will be impacted by winter late afternoon (5-6pm) demand, which is seen in March 2017 to reach 202 kW at a time when solar PV would only be generating 5 kW.

In order to find a balance of self-consumption to energy offset 4 system sizes were modelled against the load profile. In all cases a threshold level of 90% self-consumption was targeted. A more detailed shading analysis would be undertaken at installation/design stage to verify this level. All roof structures appeared suitable upon visual inspection, with no obvious issues identified. Confirmation from a structural engineer's report could be obtained if required.

A suggested system that maximises offset within the capacity of the roof is a 224 kWp system that can achieve a 91% self-consumption level and offset more than 31% of the site's electricity demand. It is noted that this is modelled based on the assumption the cogeneration unit is running, and there is no impact on cogeneration from the solar PV system. When there is surplus solar energy this will be exported rather than require the cogeneration unit operation to be modified. When planning for solar PV it will be prudent to engage with Ausgrid so that any relevant issues in terms of grid protection can be identified and included within any works.

In the event that accessing STCs is considered important Council can install a 100 kWp system across the front three north-facing roofs.

System size	Energy offset	Self-consumption
180kWp	28.53%	96.01%
202kWp	30.86%	93.24%
224kWp	31.24%	91.11%
239kWp	35.65%	86.95%

TABLE 5: SUMMARY OF SOLAR PV MODELLED RESULTS FOR BOY CHARLTON POOL

2.3.2 Retail energy rates used

The following retail energy rates and escalation rate were used in the assessment of the costs and benefits.

- Peak/Shoulder 6.103¢/kWh in 2017, rising to 6.155 ¢/kWh in 2018 and 6.24 ¢/kWh in 2019
- Offpeak 4.133¢/kWh in 2017, rising to 4.17 ¢/kWh in 2018 and 4.231 ¢/kWh in 2019
- 2.5% annual rise thereafter

These are in addition to regulated network rates as per Ausgrid's published tariffs, which are assumed to escalate at 2.5% per year.



The rates used are lower than recent trends in wholesale electricity markets owing to the timing of Council's procurement for sites in the former Manly LGA. More recent trends have seen electricity retail prices increase by more than 200% for some end users. Both the Pittwater and Warringah areas will experience rises in energy rates of this magnitude from January 2018.

Modelled solar generation was overlaid onto interval data for the site and the combined electricity rate (retail + network + envoronmental + market) applied for each hour of the year. This analysis enables both a weighted value for solar PV energy savings and peak demand / capacity savings to be estimated. These are site-specific values, and following the implementation year 2019/20 are estimated to be:

- Weighted value of solar kWh savings: 18.14 ¢/kWh
- Expected reduction in peak demand / capacity: 4.5 kVA at the applicable Ausgrid rate

2.3.3 Layout of proposed solar PV system




FIGURE 11: LAYOUT OF A 224 KWP SOLAR PV SYSTEM ON BOY CHARLTON POOL

The blue sections in the above image are solar panels in the suggested configuration. Orange polygons refer to existing roof structures.



A number of photos were taken at the site to highlight:

- Main switch room and space in the distribution board in the main switchroom to accommodate solar,
- Potential inverter location,
- Shading impact example,
- Roof structure and example of suitable screw lines for mounting



Main switch room



Potential inverter location



Front roof with suitable screw lines for mounting



Space in DB board in Main switch room



Shading impact at 8.30am



Internal roof sructure

FIGURE 12: PHOTOS OF KEY FEATURES THAT SUPPORT THE IMPLEMENTATION OF SOLAR PV AT BOY CHARLTON POOL



2.3.4 Energy flows

The expected energy flows (from grid, from solar, excess solar) were compiled by plotting the load profiles for the site and the hourly output from solar PV systems alongside one another. The two graphs below illustrate the flows in sample summer and winter weeks.




FIGURE 13: SUMMER ENERGY FLOWS WITH SOLAR PV AT BOY CHARLTON POOL




FIGURE 14: WINTER ENERGY FLOWS WITH SOLAR PV AT BOY CHARLTON POOL



2.3.5 Business case results

Modelled solar PV outputs were mapped against the energy rates and escalation rates noted above, and together with estimated capital costs was used to estimate the payback for solar PV and the performance of the project over its expected 25 year life. The results of this are summarised below.

TABLE 6: SUMMARY OF SOLAR PV BUSINESS CASE PROJECTIONS FOR BOY CHARLTON POOL

Return on Investment	
Payback period (years)	6.10
Estimated energy usage savings year 1	\$58,526
Estimated peak demand savings year 1	\$629
Estimated total savings year 1	\$59,156
Cash flow of 25 year system life (excludes capital cost)	\$1,744,429
IRR	16%
NPV	\$371,380
% of energy supplied by solar	31.24%
% of solar energy consumed	91.11%
System upfront cost	
Gross system cost fully installed by GST	\$425,600




FIGURE 15: SYSTEM LIFE CASH FLOW PROJECTION FOR BOY CHARLTON POOL

2.3.6 Components used in modelling

Modules LG 300W Mono X Inverter Fronius ECO 27-3-M

Warranty 25 year Module o/p to 83%

12 module structural warranty 10 year inverter warranty PVSYST V6.47 20/06/17 Page 1/4

Northern Beaches Council

Aquatic centre (Boy Charlton)

Grid-Connected System: Simulation parameters

Project: NBC Aquatic centre

Geographical Site Sydney Country Australia

Situation Latitude 33.9°S Longitude 151.2°E Time defined as Legal Time Time zone UT+10 Altitude 4 m

Albedo 0.20

Meteo data: Sydney MeteoNorm 7.1 station - Synthetic

Simulation variant: New simulation variant

Simulation date 20/06/17 13h06

Simulation parameters

2 orientations Tilts/Azimuths 25°/-10° and 10°/80°

Models used Transposition Perez Diffuse Perez, Meteonorm

Horizon Free Horizon
Near Shadings No Shadings

PV Arrays Characteristics (2 kinds of array defined)

PV module Si-mono Model LG 300 N1C-A3
Original PVsyst database Manufacturer LG Electronics

Sub-array "Sub-array #1"Orientation#2Tilt/Azimuth10°/80°Number of PV modulesIn series22 modulesIn parallel9 stringsTotal number of PV modulesNb. modules198Unit Nom. Power300 Wp

Array global power Nominal (STC) **59.4 kWp** At operating cond. 53.3 kWp (50°C)

Array operating characteristics (50°C) U mpp 628 V I mpp 85 A

Sub-array "Sub-array #2"Orientation#1Tilt/Azimuth25°/-10°Number of PV modulesIn series22 modulesIn parallel25 stringsTotal number of PV modulesNb. modules550Unit Nom. Power300 Wp

Array global power Nominal (STC) 165 kWp At operating cond. 148 kWp (50°C)

Array operating characteristics (50°C) U mpp 628 V I mpp 236 A

Total Arrays global power Nominal (STC) **224 kWp** Total 748 modules Module area **1227 m²** Cell area 1073 m²

Inverter Model ECO 27.0-3-S

Original PVsyst database Manufacturer Fronius International

Characteristics Operating Voltage 580-850 V Unit Nom. Power 27.0 kWac **Sub-array "Sub-array #1"** Nb. of inverters 2 units Total Power 54 kWac

Total Nb. of inverters 7 Total Power 189 kWac

Nb. of inverters 5 units

Total Power

135 kWac

PV Array loss factors

Sub-array "Sub-array #2"

Thermal Loss factor Uc (const) 20.0 W/m²K Uv (wind) 0.0 W/m²K / m/s Wiring Ohmic Loss Array#1 124 mOhm Loss Fraction 1.5 % at STC Array#2 44 mOhm Loss Fraction 1.5 % at STC Global Loss Fraction 1.5 % at STC -0.8 % Module Quality Loss Loss Fraction

PVMtodusleedvilismaatoleclsesises Australia) Loss Fraction 1.0 % at MPP

Incidence effect, ASHRAE parametrization IAM = 1 - bo (1/cos i - 1) bo Param. 0.05

PVSYST V6.47		20/06/17	Page 2/4					
Northern Beaches Council Aquatic centre (Boy Charlton)								
Grid-Connected System: Simulation parameters (continued)								
User's needs :	Unlimited load (grid)							

PVsyst Licensed to Solar Project Services (Australia)

PVSYST V6.47 20/06/17 Page 3/4

Northern Beaches Council

Aquatic centre (Boy Charlton)

Grid-Connected System: Main results

Project: **NBC** Aquatic centre

Simulation variant: New simulation variant

Main system parameters

PV Field Orientation

PV modules **PV** Array

Inverter Inverter pack User's needs System type

2 orientations Model

Nb. of modules Model Nb. of units

Grid-Connected

LG 300 N1C-A3

748 ECO 27.0-3-S

7.0

Tilt/Azimuth = 25° /- 10° and 10° /80° 300 Wp Pnom

Pnom total 224 kWp Pnom

27.00 kW ac 189 kW ac

Pnom total

Main simulation results

System Production

Produced Energy Performance Ratio PR


Unlimited load (grid)


354.2 MWh/year 86.18 %

Specific prod.

1578 kWh/kWp/year

Normalized productions (per installed kWp): Nominal power 224 kWp





New simulation variant Balances and main results

	GlobHor	T Amb	Globinc	GlobEff	EArray	E_Grid	EffArrR	EffSysR
	kWh/m²	°C	kWh/m²	kWh/m²	MWh	MWh	%	%
January	205.9	23.32	200.0	193.6	38.13	37.35	15.54	15.22
February	167.9	22.64	170.6	165.0	32.98	32.30	15.76	15.44
March	154.0	20.81	169.5	164.4	33.01	32.32	15.87	15.54
April	125.3	17.70	150.7	146.1	30.04	29.42	16.25	15.92
May	93.7	14.53	124.8	120.8	25.44	24.89	16.61	16.25
June	72.0	11.82	96.3	93.1	20.06	19.62	16.98	16.61
July	80.3	10.97	107.8	104.2	22.43	21.94	16.97	16.59
August	104.2	12.72	129.8	125.6	26.61	26.04	16.71	16.35
September	128.8	16.05	144.7	140.3	28.78	28.16	16.21	15.87
October	165.0	18.52	171.7	166.4	33.69	32.98	16.00	15.66
November	176.4	20.16	172.6	166.9	33.59	32.88	15.86	15.53
December	201.6	22.31	193.0	186.6	37.03	36.26	15.64	15.32
Year	1675.1	17.60	1831.5	1773.1	361.78	354.17	16.10	15.76

Legends: GlobHor T Amb Globlnc

GlobEff

Horizontal global irradiation Ambient Temperature Global incident in coll. plane Effective Global, corr. for IAM and shadings

EArray E_Grid FffArrR EffSysR

Effective energy at the output of the array Energy injected into grid Effic. Eout array / rough area Effic. Eout system / rough area

PVSYST V6.47 | 20/06/17 | Page 4/4

Northern Beaches Council Aquatic centre (Boy Charlton)

Grid-Connected System: Loss diagram

Project : NBC Aquatic centre
Simulation variant : New simulation variant


Main system parameters System type Grid-Connected

PV Field Orientation 2 orientations Tilt/Azimuth = 25°/-10° and 10°/80°

PV modules Model LG 300 N1C-A3 Pnom 300 Wp **PV** Array Nb. of modules 748 Pnom total 224 kWp Inverter Model ECO 27.0-3-S Pnom 27.00 kW ac Inverter pack Nb. of units 7.0 Pnom total 189 kW ac

User's needs Unlimited load (grid)

Loss diagram over the whole year





Level 32, 101 Miller Street North Sydney 2060