

Landscape Referral Response

Application Number:	DA2020/0262
Date:	19/05/2020
Responsible Officer:	Adam Urbancic
,	Lot 120 DP 526584 , 4 Bungaloe Avenue BALGOWLAH HEIGHTS NSW 2093

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings. •
- New Dwellings or

Officer comments

The proposed development is for alterations and additions to the existing dwelling house, including an attached garage and a bins store platform at the front boundary.

Council's Landscape section have assessed the application against the landscape controls of Manly DCP 2013, section 3: General Principles of Development, and section 4: Development Controls and Development Types.

No protected trees are proposed for removal and conditions of consent shall be imposed to ensure protection of existing trees. It is unclear from the development application documents if the bins store platform requires the removal of the existing tree that is located on the edge of the proposed bin area. The documents do not indicate removal. It is noted that this deciduous tree is an exempt species that does not require Council consent for removal.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Tree and vegetation protection

a) Existing trees and vegetation shall be retained and protected as follows:

i) all trees and vegetation within the site identified on the Site Plan and the Survey Plan, excluding exempt vegetation under the relevant planning instruments of legislation,

ii) all trees and vegetation located on adjoining properties,

iii) all road reserve trees and vegetation.

DA2020/0262

Page 1 of 2 http://dypxcp.northernbeaches.nsw.gov.au/eservices/pages/xc.assess/reports.aspx?id=118... 19/05/2020

Landscape Referral Response



b) Tree protection shall be generally undertaken as follows:

i) all tree protection shall be in accordance with AS4970- 2009 Protection of Trees on Development Sites, with particular reference to Section 4,

ii) removal of existing tree roots greater than 25mm is not permitted without consultation with a AQF Level 5 Arborist,

iii) any tree roots exposed during excavation with a diameter greater than 25mm within the tree protection zone must be assessed by an Arborist. Details including photographic evidence of works undertaken shall be submitted by an AQF Level 5 Arborist to the Certifying Authority,

iv) to minimise the impact on trees and vegetation to be retained and protected, no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,

v) no tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a Project Arborist on site,

vi) all structures are to bridge tree roots greater than 25mm diameter unless directed by a AQF Level 5 Arborist on site,

vii) excavation for stormwater lines is not permitted within the tree protection zone, without consultation with a AQF Level 5 Arborist,

viii) should either or all of v), vi) and vii) occur during site establishment and construction works, a AQF Level 5 Arborist shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority,

ix) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works, is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of AS 4970-2009,

x) tree pruning to enable construction shall not exceed 10% of any tree canopy, and shall be in accordance with AS4373-2009 Pruning of Amenity Trees.

c) All protected trees are to be retained for the life of the development, or for their safe natural life. Trees that die or are removed by approval must be replaced with a locally native canopy tree.

Reason: to retain and protect significant planting on development and adjoining sites.

Any request to remove a tree approved for retention under the development application is subject to a Section 4.55 modification application, or an assessment by a AQF level 5 Arborist that determines that the tree presents an imminent risk to life or property.

http://dypxcp.northernbeaches.nsw.gov.au/eservices/pages/xc.assess/reports.aspx?id=118... 19/05/2020