



essentialCERTIFIERS

ESSENTIAL FIRE SAFETY MEASURES

The following is a list of essential fire safety measures that are applicable to this building under Clause 166 of the EP&A regulations 2000.

Proposed Schedule of Essential Fire Safety Measures

Essential Service	Australian Standard	Building Code of Australia
Fire shutters	AS 1905.2 (fire resistant roller shutters)	Spec C3.4
Smoke detectors and heat detectors	AS 3786 -- 1993 amdt 4, Jan 2004	Spec E2.2a

Note: All existing and proposed fire safety measures are to be assessed annually and a copy referred to the relevant local council and to the NSW Fire Brigades. The Annual Fire Safety Statement is to be prominently displayed in each building.