

Natural Environment Referral Response - Riparian

Application Number:	DA2019/0002
To:	Penny Wood
Land to be developed (Address):	Lot 31 DP 5464 , 31 Warriewood Road WARRIEWOOD NSW 2102 Lot 30 DP 5464 , 29 Warriewood Road WARRIEWOOD NSW 2102

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application is recommended for approval with conditions.

Sediment and erosion controls must be installed prior to any work on site and maintained until groundcover is re-established. Particular care should be taken to ensure sediment from the site does not enter the street drains or the stormwater pit on the site, as this will impact the bio-retention basin for 29-31 Warriewood Road.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site (DACNED06)