



TELEPHONE: 13 13 65

EMAIL: development@ausgrid.com.au

This letter is Ausgrid's response under clause 45(2) of the State Environmental Planning Policy (Infrastructure) 2007.

Ausgrid does not object to the proposed development.

The applicant/developer should note the following information regarding any development proposal near existing electrical network assets.

24-28 Campbell St
Sydney NSW 2000
All mail to
GPO Box 4009
Sydney NSW 2001
T +61 2 13 13 65
ausgrid.com.au

Ausgrid Underground Cables are in the vicinity of the development

Care should be taken to ensure that construction activities do not interfere with existing underground cables located in the footpath or adjacent roadways.

It is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area. Information regarding the position of cables along footpaths and roadways can be obtained by contacting Dial Before You Dig (DBYD).

The following points should be taken into consideration.

Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed.

Should ground anchors be required in the vicinity of Ausgrid underground cables, the anchors must not be installed within 300mm of any cable, and the anchors must not pass over the top of any cable.

In addition to DBYD the proponent should refer to the following documents to support safety in design and construction:

- SafeWork Australia – Excavation Code of Practice.
- Ausgrid's Network Standard NS156 which outlines the minimum requirements for working around Ausgrid's underground cables. This document can be found by visiting the Ausgrid website via www.ausgrid.com.au.
- The Ausgrid Quick Reference Guide for Safety Clearances "Working Near Ausgrid Assets - Clearances". This document can also be found by visiting the Ausgrid website : www.ausgrid.com.au/Your-safety/Working-Safe/Clearance-enquiries

For new connections or to alter the existing electrical connection to the property from the Ausgrid network, the proponent should engage an Accredited Service Provider and submit a connection application to Ausgrid as soon as practicable. Visit the Ausgrid website for further details:

<https://www.ausgrid.com.au/Connections/Get-connected>

Should you have any enquiries please contact Ausgrid at Development@ausgrid.com.au

Regards,
Ausgrid Development Team