

Engineering Referral Response

Application Number:	DA2019/0510
To:	Benjamin Price
Land to be developed (Address):	Lot 12 DP 654177 , 183 Barrenjoey Road NEWPORT NSW 2106

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed development is located within a Geotechnical Hazard H2 area. In accordance with Clause B3.1 Landslip Hazard of Pittwater DCP 2014, which requires a risk assessment to be undertaken (Geotechnical Risk Management Policy for Pittwater) has not been submitted. In this regards a revised geotechnical report is required addressing the Geotechnical Risk Management Policy for Pittwater - 2009. The report must include comments for the proposed level spreader located at the rear of the dwelling.

As a result the DA cannot be supported.

Referral Body Recommendation

Recommended for refusal

Refusal comments

Recommended Engineering Conditions:

Nil.