

Wastewater Management

PO Box 748
ROUND CORNER NSW 2158
Ph:0418 278895
02 45728634
awtsservice@telstra.com

28th May, 2024

Mr. & Mrs. Sherlock,
Lot 416 Cooyong Road,
TERREY HILL NSW

Dear Mr. & Mrs. Sherlock,

Re: Wastewater Treatment System

Presently existing on site is a Super-Treat Aerated Wastewater Treatment System (AWTS).

We have carried out repairs to the system replacing a failed pump-out chamber and damaged air manifold.

Following these repairs the system is in good working order, with irrigation delivered by way of spray irrigation to lawn area located rear right of the system.

Any system failure is recorded by way of alarm located at the system.

Yours faithfully,

Gary Hobart
