

Engineering Referral Response

Application Number:	DA2021/1596
Date:	15/09/2021
To:	Phil Lane
Land to be developed (Address):	Lot 46 DP 13620 , 967 Barrenjoey Road PALM BEACH NSW 2108 Lot LIC 402863 , 967 Barrenjoey Road PALM BEACH NSW 2108

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The site is affected by the H1 Geotechnical Hazard and as such a Geotechnical report including Forms 1 and 1A in accordance with Council's Geotechnical Policy for the proposed works must be submitted with the application.

Development Engineers cannot support the application due to insufficient information to address clause B3.1 of Pittwater DCP.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

Nil.