

Building Assessment Referral Response

Application Number:	DA2019/0114
To:	Rebecca Englund
Land to be developed (Address):	Lot A DP 39108 , 267 Condamine Street MANLY VALE NSW 2093 Lot B DP 39108 , 267 Condamine Street MANLY VALE NSW 2093

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application proposes four (4) residential levels that are located above ground floor level retail tenancies, with two (2) levels of basement car parking located under. The building proposes twenty seven (27) sole occupancy units. Vehicular and pedestrian access is provided to the building from Kenneth Street.

No objections subject to conditions to ensure compliance with the National Construction Code.

Recommended Building Assessment Conditions

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.