

# Nationwide House Energy Rating Scheme\* Certificate



Certificate number: **0004389227-02**

Certificate Date: **29 Jun 2020**

★ Star rating: **6.8**

BERS Pro v4.3.0.0 (3.13) cannot be used to model 'roof windows'. Roof windows are 'openable or fixed windows in a roof' and do not have a shaft, as distinct from skylights which incorporate a built-in shaft and are not ventilated. BERS Pro v4.3 can only model skylights. If a roof window is present on the floor plan then this certificate is not valid.

## Assessor details

Accreditation

number: **VIC/BDAV/12/1441**

Name: **Ian Fry**

Organisation: **Frys Energywise**

Email: **comply@frysenergywise.com.au**

Phone: **02 9899 2825**

Declaration of interest: **The Assessor has provided design advice to the Applicant**

Software: **BERS Pro v4.3.0.2f (3.13)**

AAO: **BDAV**

## Overview

### Dwelling details

Street: **Unit GF, 97 Waterview Street**

Suburb: **Mona Vale**

State: **NSW**

Postcode: **2103**

Type: **New Dwelling**

NCC Class: **1A**

NatHERS

climate zone: **56**

Lot/DP

number: **8/7953**

Exposure: **Suburban**

### Key construction and insulation materials

(see following pages for details)

Construction: **Brick Veneer**

**Roof Tiles**

**Waffle pod slab 225 mm**

Insulation:

**R1.5 wall insulation**

**R3.5 ceiling insulation**

**No floor insulation**

Glazing:

**STG-007-01 A Aluminium Sliding**

**Window SG 3Clr**

### Net floor area (m<sup>2</sup>)

Conditioned: **46.0**

Unconditioned: **4.0**

Garage: **0.0**

TOTAL: **50.0**

### Annual thermal performance loads (MJ/m<sup>2</sup>)

Heating: **16.0**


Cooling: **25.5**

TOTAL: **41.5**

### Plan documents

Plan ref/date: **29913901**

Prepared by: **PG**



### Ceiling penetrations

(see following pages for details)

Sealed: **2**

Unsealed: **0**

TOTAL:\*\* **2**

\*\*NOTE: This total is the maximum number of ceiling penetrations allowed to a ceiling (under a roof) for this certificate. **If this number is exceeded in construction then this certificate IS NOT VALID and a new certificate is required.** Loss of ceiling insulation for the penetrations listed has been taken into account with the rating.

Principle downlight type: **Unknown**

### Window selection - default windows only


Note on allowable window values:  
Only a 5% tolerance to the nominated SHGC window values shown on page 2 can be used with this rating.

Note: Only a +/- 5% SHGC tolerance is allowed with this rating.

NB: This tolerance ONLY applies to SHGC, the U-value can always be lower but not higher than the values stated on page 2.

**If any of windows selected are outside the 5% tolerance then this certificate is no longer valid and the dwelling will need to be rerated to confirm compliance.**

Scan to access this certificate online and confirm this is valid.



# Nationwide House Energy Rating Scheme\* Certificate

Certificate number: 0004389227-02

Certificate Date:

29 Jun 2020

★ Star rating:

6.8



## Building features

### Window type and performance value

Window ID	Window type	U-value	SHGC
STG-007-01 A	STG-007-01 A Aluminium Sliding Window SG 3Clr	6.3	0.73
STG-002-01 A	STG-002-01 A Aluminium Awning Window SG 3Clr	6.5	0.65
STG-005-06 A	STG-005-06 A Aluminium Sliding Door SG 638CP	4.4	0.45
STG-007-07 A	STG-007-07 A Aluminium Sliding Window SG 638CP	4.5	0.44

### Window schedule

Location	Window ID	Window no.	Height (mm)	Width (mm)	Orientation	Outdoor shade
Bedroom 1	STG-007-01 A	n/a	1200	1500	NE	No Shading
Bedroom 2	STG-007-01 A	n/a	1200	1500	NE	No Shading
Bath	STG-002-01 A	n/a	1000	600	SE	No Shading
Kitchen/Living	STG-005-06 A	n/a	2100	2300	NE	No Shading
Kitchen/Living	STG-007-07 A	n/a	600	2400	NW	No Shading

### Roof window and skylight type and performance value

ID	Window type	U-value	SHGC
None Present			

### Roof window and skylight schedule

Location	ID	Roof window/skylight no.	Area (m²)	Orientation	Outdoor shade	Indoor shade/diffuser
None Present						

### External wall type

ID	Wall type	Insulation	Wall wrap or foil
EW-1	Brick Veneer	Bulk Insulation R1.5	No

### External wall schedule

Location	ID	Width (mm)	Height (mm)	Orientation	Fixed Shade	Eaves (mm)
Bedroom 1	EW-1	2895	2450	SE	No	600
Bedroom 1	EW-1	3795	2450	NE	No	600
Bedroom 2	EW-1	2990	2450	NE	No	600
Bath	EW-1	1795	2450	SE	No	600
Bath	EW-1	2095	2450	SW	No	600
Laundry	EW-1	1190	2450	SW	No	600
Kitchen/Living	EW-1	4095	2450	NE	No	600
Kitchen/Living	EW-1	7595	2450	SW	No	600
Kitchen/Living	EW-1	4700	2450	NW	No	600

### Internal wall type

Wall type	Area (m²)	Insulation	Wall wrap or foil
IW-1 - Cavity wall, direct fix plasterboard, single gap	42.0	No insulation	No

# Nationwide House Energy Rating Scheme\* Certificate

Certificate number: **0004389227-02**

Certificate Date:

**29 Jun 2020**

★ Star rating:

**6.8**

## Building features continued

### Floors

Location	Construction	Area (m <sup>2</sup> )	Sub floor ventilation	Added insulation	Covering
Bedroom 1	Waffle pod slab 225 mm 100mm	9.7	None	Waffle Pod 225mm	Carpet+Rubber Underlay 18mm
Bedroom 2	Waffle pod slab 225 mm 100mm	9.3	None	Waffle Pod 225mm	Carpet+Rubber Underlay 18mm
Bath	Waffle pod slab 225 mm 100mm	3.6	None	Waffle Pod 225mm	Ceramic Tiles 8mm
Laundry	Waffle pod slab 225 mm 100mm	0.8	None	Waffle Pod 225mm	Ceramic Tiles 8mm
Kitchen/Living	Waffle pod slab 225 mm 100mm	26.3	None	Waffle Pod 225mm	Ceramic Tiles 8mm

### Ceiling type

Location	Construction	Added insulation	Roof space above
Bedroom 1	Plasterboard	Bulk Insulation R3.5	Yes
Bedroom 2	Plasterboard	Bulk Insulation R3.5	Yes
Bath	Plasterboard	Bulk Insulation R3.5	Yes
Laundry	Plasterboard	Bulk Insulation R3.5	Yes
Kitchen/Living	Plasterboard	Bulk Insulation R3.5	Yes

### Ceiling penetrations

Location	Number	Type	Diameter (mm)	Sealed/unsealed
Bath	1	Exhaust Fans	300	Sealed
Laundry	1	Exhaust Fans	300	Sealed

### Ceiling fans

Location	Number	Diameter (mm)
None Present		

### Roof type

Construction	Added insulation	Roof colour
Roof Tiles	Foil, Gap Above, Reflective Side Down, Anti-glare Up	Dark

# Nationwide House Energy Rating Scheme\* Certificate

Certificate number: 0004389227-02

Certificate Date: 29 Jun 2020

★ Star rating: 6.8



## Additional information

## Explanatory notes

### About this report

Residential energy ratings address the quality of the building fabric i.e. walls, windows, floors and roof/ceilings. Ratings do not cover the energy or water efficiency of appliances including heating and cooling, hot water, dishwashers, ovens, fridges, TVs etc. or solar panel or water tank requirements. The efficiency or specification of these items is generally covered by other regulations, standards or guidelines.

### General Information

A NatHERS House Energy Rating is a comprehensive, dynamic computer modelling evaluation of the floorplans, elevations and specifications to predict an energy load of a home. Not all of us use our homes in the same way, so ratings are generated using standard assumptions. This means homes can be compared across the country.

The actual energy consumption of your home may vary significantly from the predicted energy load figures in the report depending on issues such as the size of your household and your personal preferences, e.g. in terms of heating or cooling.

While the figures are an indicative guide to energy use, they can be used as a reliable guide for comparative purposes between different house designs and for demonstrating that the design meets the required regulatory compliance.

Homes that are energy efficient use less energy, are warmer in winter, cooler in summer and cost less to run. The higher the star rating the more energy efficient.

This NatHERS House Energy Rating report was carefully prepared by your assessor on the basis of comprehensive modelling using standard procedures to rate your home using the underlying engine developed by the Australian Commonwealth Scientific and Industrial Research Organisation (CSIRO).

All information relating to energy loads presented in this report is based on a range of standard assumptions in order to allow for comparisons with reports prepared for other homes and to demonstrate minimum regulatory compliance.

The standard assumptions include figures for occupancy, indoor air temperature and are based on a unique climate file for your region.

### Accredited Assessors

To ensure you get a high-quality, professional NatHERS House Energy Rating report, you should always use an accredited assessor, accredited assessors are members of a professional body called an Assessor Accrediting Organisation (AAO).

AAOs have specific quality assurance processes in place and continuing professional development requirements to maintain a high and consistent standard of assessments across the country. Non-accredited assessors do not have this level of quality assurance or any on-going training requirements.

If you have any questions or concerns about this report, please direct them to your assessor in the first instance.

If your assessor is unable to address your questions or concerns, please contact their AAO listed under 'assessor details'. You can also find a range of information about accredited assessors on the AAO websites.

### Disclaimer

The energy values quoted are for comparison purposes only; they are not a prediction of actual energy use. This rating only applies to the floor plan, construction details, orientation and climate as submitted and included in the attached drawing set that bears a stamp with the same number as this certificate. Changes to any of these details could affect the rating.

### Contact

For more information on the Nationwide House Energy Rating Scheme (NatHERS), visit [www.nathers.gov.au](http://www.nathers.gov.au)

For more information on energy efficient design and insulation visit [www.yourhome.gov.au](http://www.yourhome.gov.au)