

## Natural Environment Referral Response - Coastal

<b>Application Number:</b>	DA2024/0876
<b>Proposed Development:</b>	Construction of a swimming pool and associated works
<b>Date:</b>	17/07/2024
<b>Responsible Officer</b>	Olivia Ramage
<b>Land to be developed (Address):</b>	Lot 388 DP 19651 , 32 Norma Road PALM BEACH NSW 2108

### Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The applicant seeks development consent to undertake the following:

Scope of Works includes:

- Swimming pool (6640mm x 5905mm).
- Installation of pool equipment in an acoustic enclosure.
- Construction of a pool deck.
- Construction of a 1.2m high stone wall as pool barrier
- Pool Fence: 1.2m high frameless glass pool fence
- Pool Fence: 1.2m high aluminium pool fence
- Improvements to existing landscape including retaining and relocating existing Frangipani tree that's under 5m in height.

This application was assessed in consideration of:

- Supplied plans and reports;
- *Coastal Management Act (2016)*
- State Environmental Planning Policy (Resilience and Hazards) 2021 (section 2.11 & 2.12);
- Relevant LEP and DCP clauses.

Comment: **SUPPORTED WITH CONDITIONS**

### State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Use Area' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021 (SEPP R & H). Hence, Clauses 2.11 and 2.12 of the CM (R & H) apply for this DA.

**Comment:**

On internal assessment, the modifications outlined within the DA including the Statement of Environmental Effects dated 21 June by Formed Garden Design and Construction satisfies requirements under clause 2.11 & 2.12 of the SEPP R&H. As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

**Pittwater LEP 2014 and Pittwater 21 DCP**

No other coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Natural Environment Conditions:**

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

**Erosion and Sediment Control Plan**

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in

the Landcom publication *Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition* (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities);
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls;
- North point and scale.

Details demonstrating compliance are to be submitted to the Certifier for approval prior to the issue of the Construction Certificate.

Reason: To protect the environment from the effects of sedimentation and erosion from development sites.

## **CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

### **Installation and Maintenance of Sediment and Erosion Control**

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **Stockpiling materials**

During construction, all material associated with works is to be contained at source, covered and must be within the construction area. All material is to be removed off site and disposed of according to local regulations. The property is to be kept clean and any building debris removed as frequently as required to ensure no debris enters receiving waters.

Reason: To ensure pollution control measures are effective to protect the aquatic habitats within receiving waters throughout the construction period.