

## Building Assessment Referral Response

<b>Application Number:</b>	DA2020/0029
<b>To:</b>	Alex Keller
<b>Land to be developed (Address):</b>	Lot 131 DP 708044 , 11 - 17 Wilmette Place MONA VALE NSW 2103 Lot 17 DP 707610 , 11 - 17 Wilmette Place MONA VALE NSW 2103

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### Fire Safety Upgrade

The recommendations made in the Fire Engineering Report prepared by MCD Fire Engineering, dated 6 November, 2019, Report Ref No. S19151 are to be carried out to the building.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety

## CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

### **Fire Safety Upgrade**

The recommendations made in the Fire Engineering Report prepared by MCD Fire Engineering, dated 6 November, 2019, Report Ref No. S19151 are to be carried out to the building.

Details demonstrating implementation are to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

Reason: To ensure adequate provision is made for fire safety in the premises for building occupant safety.

### **Fire Safety Matters**

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW. Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate. Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.