

Environmental Health Referral Response - commercial use

Application Number:	DA2023/1107
Proposed Development:	Change of use and alterations and additions to Office C for the purpose of a child care centre and landscaping
Date:	10/10/2023
To:	Nick Keeler
Land to be developed (Address):	Lot 1 DP 1282038 , 4 - 8 Inman Road CROMER NSW 2099

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments

General Comments

This applicant is seeking consent for demolition and construction at 4-8 Inman Road, Cromer. Internal alterations are proposed to include a childcare center (CCC). minor earthworks, 20 car park spaces to the CCC within the basement car parking area. Total of 120 children. A kitchen and laundry for the CCC is also proposed.

The operating hours for the center are to be 7am to 6pm Mondays to Fridays and 8am to 3pm Saturdays, with no operation on Sundays. In relation to food safety, the fitout can be adequately conditioned.

Environmental Health recommends approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE**

Registration of food Business

The food business must be registered with the appropriate regulatory authority, prior to the Occupation Certificate being issued.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any occupation certificate, certification is to be provided to the Principal Certifier by a suitably qualified person demonstrating that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Reason: To ensure that the kitchen complies with Australian Standard design requirements.

Mechanical Ventilation certification

Where Mechanical ventilation is required to be installed in the food premises it must comply with the following:

- Australian Standard (AS) 1668.2 “The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings”; and
- Any external exhaust discharge must be above the roofline and discharged in a manner that is not likely to cause an amenity impact.

Certification is to be provided to the Principal Certifier prepared by a suitably qualified person to demonstrate that the mechanical ventilation complies with the above requirements.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2 and to prevent amenity impacts.