

## Building Assessment Referral Response

<b>Application Number:</b>	DA2022/0145
<b>Date:</b>	16/03/2022
<b>To:</b>	Anne-Marie Young
<b>Land to be developed (Address):</b>	Lot CP SP 32072 , 812 Pittwater Road DEE WHY NSW 2099 Lot CP SP 32071 , 4 Delmar Parade DEE WHY NSW 2099

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### Building Code of Australia Fire Safety Requirements

The Building Code of Australia fire safety measures for the building as detailed and recommended in the Design Compliance Report prepared by Max Shutter & Associates, dated 25/11.2021, Report Ref No. MSA2246\_BCA\_DA\_01 including any associated Fire Engineering / Performance Solution are to be considered as part of the assessment of the Construction Certificate. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

### **Building Code of Australia Access**

Access and facilities to and within the building are to be provided for Persons with a Disability and are to comply with the Building Code of Australia and AS 1428.1. In this regard the recommendations contained within the Statement of Compliance Report prepared by Accessible Building Solutions dated 3/12/2021 are to be taken into consideration as part of the assessment of the Construction Certificate. Details are to be provided to the Certifying Authority prior to the issue of the Construction Certificate and be implemented prior to occupation of the building.