

Natural Environment Referral Response - Flood

Application Number:	DA2021/2579
Date:	17/03/2022
To:	Dean Pattalis
Land to be developed (Address):	Lot 10 DP 17768 , 87 Wimbledon Avenue NORTH NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The site currently contains a two storey dwelling with an attached brick carport and a fibro shed.

The majority of site is affected by flooding and is located in a high flood risk precinct.

The 1% AEP flood depth is 1.89m, 1% AEP water level is RL 3.05 AHD, FPL is 3.55 m AHD and PMF is 5.03 m AHD.

The DA involves demolishing the existing fibro shed at the rear and constructing an in ground pool an associated fencing at the same location.

Details on the proposed pool fencing have not been provided. New fencing shall be open to allow for the unimpeded movement of flood waters. It must be designed with a minimum of 50% open area from the natural ground level up to the 1% AEP flood level. Openings should be a minimum of 75 mm x 75 mm.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION
CERTIFICATE**

Flooding

In order to protect property and occupants from flood risk the following is required:

Flood Effects Caused by Development – A2

There is to be no filling of the land or any other reduction of the available flood storage which results in a net loss of storage below the 1% AEP flood level of 3.05 m AHD.

Building Components and Structural Soundness – B1

All new development below the Flood Planning Level of shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

Building Components and Structural Soundness – B3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level. All existing electrical equipment and power points located below the Flood Planning Level must have residual current devices installed to cut electricity supply during flood events.

Fencing – F1

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open to allow for the unimpeded movement of flood waters. It must be designed with a minimum of 50% open area from the natural ground level up to the 1% AEP flood level. Openings should be a minimum of 75mm x 75mm.

Storage of Goods – G1

Storage areas for hazardous or potentially polluting materials shall not be located below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.

Recommendations

The development must comply with the recommendations outlined in the Flood Risk Management Report prepared by Pittwater Data Services dated 15/12/21.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.