

Building Assessment Referral Response

| | |
|--|--|
| Application Number: | DA2023/0677 |
| Proposed Development: | Alterations and additions to a dwelling house including a carport and conversion of a garage to secondary dwelling |
| Date: | 27/06/2023 |
| To: | Phil Lane |
| Land to be developed (Address): | Lot 8 DP 13020 , 28 Maranui Avenue DEE WHY NSW 2099 |

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Weatherproofing of Masonry

The existing building that is proposed to be converted to a secondary dwelling is required to comply with Part H2P2 of the National Construction Code –'Weatherproofing'.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for building occupant health and amenity.

Fire Separation of External Walls

The external walls of the proposed Class 1 building (Secondary Dwelling) and any openings within these walls is required to comply with Clause 9.2.1 of the National Construction Code – Housing Provisions ‘External walls of a Class 1 building)’. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety