

Building Assessment Referral Response

Application Number:	REV2019/0056
To:	Lashta Haidari
Land to be developed (Address):	Lot 2 DP 1241568 , 888 Pittwater Road DEE WHY NSW 2099

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

Recommended Building Assessment Conditions

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and the NSW Fire Brigade.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and the NSW Fire Brigade an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.