

Lay Lech, Centre Manager
Revelop Pty Ltd
E: lay@revelop.com.au
A: Suite 506, Level 5, 55 Phillip Street
Parramatta, NSW 2150

Site Location: Forestay Shopping Centre
Reference: GR23239-2A
Report Date: 21/12/2023

RE: Additional Groundwater Information - Forestay Shopping Centre, Frenchs Forest, NSW

CEC Geotechnical Pty Ltd, has been engaged by Revelop Pty Ltd to carry out the geotechnical investigation and assessment at **Forestay Shopping Centre, Frenchs Forest, NSW**.

Based on our investigation of water level monitoring, available hydrogeological data, and information about the site, it was observed and recorded that the permanent ground water level is below the basement level.

It can be noted that minor seepage and perched water can be expected during construction, which can be managed by a conventional sump and pump system.

Furthermore, a geotechnical engineer will need to confirm no permanent groundwater will be encountered during the construction phase. In the event that the permanent groundwater is encountered a dewatering management and monitoring plan will need to be prepared and implemented.

This letter and associated documentation and the information have been prepared solely for the use of Revelop Pty and any reliance assumed by third parties on this letter shall be at such parties' own risk. Any ensuing liability resulting from use of the report by third parties cannot be transferred to CEC Geotechnical Pty Ltd, its directors or employees. The conclusions and recommendations of this report should be read in conjunction with the entire report.

For and on behalf of CEC Geotechnical Pty Ltd

Shyam Ghimire



Principal Engineering Geologist
B.Sc. M.Sc. AIG. RPgeo (Geotechnical Engineering)