

## Natural Environment Referral Response - Riparian

<b>Application Number:</b>	DA2022/1175
<b>Date:</b>	07/10/2022
<b>To:</b>	Phil Lane
<b>Land to be developed (Address):</b>	Lot 9 DP 25048 , 15 Bridgeview Crescent FORESTVILLE NSW 2087

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

#### Riparian Comments

This application has been assessed against relevant legislation and policy relating to waterways, riparian areas, and groundwater. This site is adjacent to Middle Harbour and as such the development must not significantly impact on the biophysical, hydrological or ecological integrity of Middle Harbour, or on the quantity and quality of surface and ground water flows to Middle Harbour. Sediment and erosion controls must be installed prior to any disturbance of soil on site and maintained until all work is complete and groundcover re-established.

This application, subject to conditions, is recommended for approval as it is unlikely to have an adverse effect on the integrity and resilience of the biophysical, ecological and hydrological environment of Middle Harbour if conditions are adhered to.

The proposal is therefore supported.

Sydney Regional Environment Plan (Sydney Harbour Catchment), 2005  
Harbour Foreshores & Waterways Area

The subject site is located within the Sydney Harbour Catchment and is identified as being within the Foreshores and Waterways Area. Hence Part 2, Clause 14 and Part 3, Division 2 apply in assessing this DA.

On internal assessment it is determined that the Planning Principles and Matters for Consideration of the Area have been met.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Natural Environment Conditions:**

**CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

**Installation and Maintenance of Sediment and Erosion Controls**

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prepared by <INSERT> prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.