

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2025/0166
Proposed Development:	Alterations and additions to a dwelling house
Date:	10/04/2025
To:	Jordan Howard
Land to be developed (Address):	Lot 3 DP 415914 , 53 Kenneth Road MANLY VALE NSW 2093

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore

And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The plans indicate that no works are proposed within the adjoining Council Reserve.

The Stormwater Report indicates that new down pipes and lines are to tap into the existing stormwater system.

It is unclear from the Report where the existing system discharges.

If further information is required from Council's Development Engineers regarding stormwater, clarification should be sought about the adequacy of the existing system and whether discharge of the stormwater complies with the relevant standards or policies. If uncontrolled, the stormwater would discharge directly into the Council Reserve.

Conditions have been provide to protect Council assets on the adjoining reserve.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period.

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

Dilapidation Report of Land Owned or Managed by Council

A dilapidation report, established at the commencement of the works, shall contain a survey of pre-existing land features including photographic record of the Land under Council's care, control, and management adjoining the development, detailing the physical condition of items such as, but not exclusively limited to, physical assets such as crossovers, driveways, footpaths, utilities, furniture, play equipment, trees, gardens, lawn areas, bushland, and any rock outcrops.

This dilapidation report shall be submitted to Council and the Principal Certifier prior to commencement of works, and shall be the basis for rectification of any damage to Council's assets as listed in the Post Construction Dilapidation report submitted prior to the issue of the Occupation Certificate.

Any damage to these assets during the works must be replaced like for like to the satisfaction of the Principal Certifier, and shall be subject to acceptance by Council.

The applicant may be held liable to any damage to public infrastructures in the vicinity of the site, where such damage is not accurately recorded under the requirements of this condition. In this regard, where required, the damage deposit lodged by the applicant may be used by Council to repair such damage on Council's property.

Reason: Protection of Council's assets.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

No Access Through Land Owned or Managed by Council

Site access is not approved for delivery of materials nor construction of the development through adjacent land owned or managed by Council, without the written approval of Council.

Reason: Public safety, landscape amenity and tree protection.

Storage of Materials on Land Owned or Managed by Council Prohibited

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

Protection of Council's Public Assets

Any damage to Council's public assets shall be made good by the applicant, and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to, the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993.

Existing trees shall be protected in accordance with AS4970-2009 Protection of Trees on Development Sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor canopy disturbance.

Reason: To protect and/or restore any damaged public asset.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Removal of All Temporary Structures/Materials and Construction Rubbish

Once construction has been completed all silt and sediment fences, silt, rubbish, building debris, straw bales and temporary fences/bunds are to be removed from the site.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of an Occupation Certificate.

Reason: To protect reserve amenity and public safety.