

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2020/0789
Date:	30/07/2020
To:	Gareth David
Land to be developed (Address):	Lot 4 DP 242868 , 28 Borghis Street DAVIDSON NSW 2085

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The site adjoins Davidson Park, under the control of the National Parks and Wildlife Service.

No objections are raised regarding Council's reserves. General conditions have been included regarding erosion control.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area, in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period.

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: to protect the surrounding environment from the effects of sedimentation and erosion from the site.