BASIX Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A378343

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

Secretarv Date of issue: Monday, 22, June 2020 To be valid, this certificate must be lodged within 3 months of the date of issue.



Planning, Industry & Environment

| Project address | |
|-----------------------|-----------------------------------|
| Project name | 87 ALEXANDRA _ |
| Street address | 87 ALEXANDRA Crescent BAVIEW 2104 |
| Local Government Area | Northern Beaches Council |
| Plan type and number | Deposited Plan 29283 |
| Lot number | 3 |
| Section number | |
| Project type | |
| Dwelling type | Separate dwelling house |
| | |

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: LEECH HARMON ARCHITECTS

ABN (if applicable): 49002517875

| Fixtures and systems | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|---------------------|---------------------------------------|--------------------|
| Hot water | | | |
| The applicant must install the following hot water system in the development: gas instantaneous. | \checkmark | | \checkmark |
| Lighting | | | |
| The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps. | | ~ | ~ |
| Fixtures | | | |
| The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating. | | \checkmark | \checkmark |
| The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating. | | \checkmark | \checkmark |
| The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating. | | \checkmark | |

| Construction | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check | | |
|--|--|---|--------------------|--|--|
| Insulation requirements | | | | | |
| The applicant must construct the new or altere the table below, except that a) additional insula is not required for parts of altered construction | ~ | ~ | ~ | | |
| Construction | Additional insulation required (R-value) | Other specifications | | | |
| concrete slab on ground floor. | nil | | | | |
| floor above existing dwelling or building. | nil | | | | |
| external wall: brick veneer | R1.16 (or R1.70 including construction) | | | | |
| external wall: framed (weatherboard, fibro, metal clad) | R1.30 (or R1.70 including construction) | | | | |
| external wall: cavity brick | nil | | | | |
| flat ceiling, pitched roof | ceiling: R2.50 (up), roof: foil/sarking | medium (solar absorptance 0.475 - 0.70) | | | |
| raked ceiling, pitched/skillion roof: framed | ceiling: R2.50 (up), roof: foil/sarking | medium (solar absorptance 0.475 - 0.70) | | | |
| flat ceiling, flat roof: framed | ceiling: R1.08 (up), roof: foil backed blanket (75 mm) | medium (solar absorptance 0.475 - 0.70) | | | |

| | requirements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|---|---|--|--|---|---|--|----------------------|---------------------------------------|--------------------|
| Windows | and glazed do | ors | | | | | | | |
| The applicant must install the windows, glazed doors and shading devices, in accordance with the specifications listed in the table below. Relevant overshadowing specifications must be satisfied for each window and glazed door. | | | | | | \checkmark | | ~ | |
| The following requirements must also be satisfied in relation to each window and glazed door: | | | | | | | \checkmark | \checkmark | |
| have a U-v must be ca | value and a Solar l alculated in accord | Heat Gair Jance with | n Coefficie National | ent (SHGC) r Fenestratio | no greater than that listed in the tab | ar glazing, or toned/air gap/clear glazing must le below. Total system U-values and SHGCs s. The description is provided for information | | ~ | ~ |
| | | | | | f each eave, pergola, verandah, bal than 2400 mm above the sill. | cony or awning must be no more than 500 mm | \checkmark | \checkmark | \checkmark |
| Pergolas v | Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35. | | | | | | | \checkmark | \checkmark |
| | | | | | | ch they are situated, unless the pergola also | | 1 | |
| | · · | | | | ens must not be more than 50 mm. | | - | Ť | Ň |
| | s and glazed o | doors gl | lazing r | equireme | nts | | - | Ť | Ť |
| | · · | doors gl | | equireme | | Frame and glass type | _ | · · | |
| Window / | s and glazed o | doors gl Area of glass inc. frame | azing r Oversha Height | equireme adowing Distance | nts | | | · · | |
| Window / no. | rs and glazed c door Orientation | doors gl Area of glass inc. frame (m2) | azing r Oversha Height (m) | equireme adowing Distance (m) | nts Shading device eave/verandah/pergola/balcony | Frame and glass type timber or uPVC, toned/air gap/clear, | | · · | |
| Window / no. W1 | vs and glazed of door Orientation | Area of glass inc. frame (m2) 7.1 | Azing r Oversha Height (m) | equiremen adowing Distance (m) 0 | nts Shading device eave/verandah/pergola/balcony >=450 mm eave/verandah/pergola/balcony | Frame and glass type timber or uPVC, toned/air gap/clear, (U-value: 3.64, SHGC: 0.42) timber or uPVC, clear/air gap/clear, | | | |
| Window / no. W1 W2 | rs and glazed of door Orientation | Area of glass inc. frame (m2) 7.1 3.15 | Oversha Height (m) 0 | equiremen adowing Distance (m) 0 | Shading device Shading device eave/verandah/pergola/balcony >=450 mm eave/verandah/pergola/balcony >=900 mm | Frame and glass type timber or uPVC, toned/air gap/clear, (U-value: 3.64, SHGC: 0.42) timber or uPVC, clear/air gap/clear, (U-value: 3.67, SHGC: 0.59) timber or uPVC, clear/air gap/clear, | | | |

| Glazing requ | irements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|----------------------|-------------|---|--------------------------|---------------------------|----------------|---|---------------------|---------------------------------------|--------------------|
| Window / door no. | Orientation | Area of glass inc. frame (m2) | Oversha Height (m) | dowing Distance (m) | Shading device | Frame and glass type | | | |
| W6 | S | 0.9 | 0 | 0 | none | timber or uPVC, clear/air gap/clear, (U-value: 3.67, SHGC: 0.59) | | | |

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a " / " in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "
"
"
"
"
"
"
"
"
"
"
"
"
Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a " / " in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.