

Building Assessment Referral Response

Application Number:	DA2019/0398
To:	Kye Miles
Land to be developed (Address):	Lot 3 DP 231428 , 76 Arnhem Road ALLAMBIE HEIGHTS NSW 2100

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Secondary Dwelling above a 'non-appurtenant private garage

Where building works involve a Class 1a Secondary Dwelling above a non-appurtenant private garage, fire separation works are to be carried out in accordance with Part 3.7 of the Building Code of Australia –'Fire Safety' and NSW 1.1 Additions.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety