

Engineering Referral Response

Application Number:	Mod2024/0035
Proposed Development:	Modification of Development Consent DA2022/0888 granted for Alterations and additions to a dwelling house including a garage, shed and carport
Date:	19/02/2024
To:	Adam Croft
Land to be developed (Address):	Lot 259 DP 752017 , 259 / 0 Aumuna Road TERREY HILLS NSW 2084

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

I have reviewed the Statement of Modification and other supporting documents and have no objections to the proposed development subject to the retention of the existing engineering conditions and the inclusion of the recommended engineering conditions of consent.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Geotechnical Report Recommendations have been Incorporated into Designs and Structural Plans

The recommendations identified in the Geotechnical Report referenced in Condition 1 of this consent are to be incorporated into the construction plans. Details demonstrating compliance are to be submitted to the Certifier prior to the issue of the construction certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.