

# Landscape Referral Response

Application Number:	DA2020/0830
Date:	31/07/2020
Responsible Officer:	Kent Bull
Land to be developed (Address):	Lot 327 DP 12316 , 10 Kimo Street NORTH BALGOWLAH NSW 2093

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc).
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

### Officer comments

No significant landscape features are to be affected by the proposal. No objections to approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### **Recommended Landscape Conditions:**

## CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

## Tree protection

- (a) Existing trees which must be retained
- i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
  - ii) Trees located on adjoining land
- (b) Tree protection
  - i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
  - ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
  - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
  - iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause
  - E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
  - v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

DA2020/0830 Page 1 of 1