

RECEIVED
15 JUN 2017
BY:



EssentialCERTIFIERS

ESSENTIAL FIRE SAFETY MEASURES

The following is a list of essential fire safety measures that are applicable to this building under Clause 166 of the EP&A regulations 2000.

Proposed Schedule of Essential Fire Safety Measures

| Essential Service | Australian Standard | Building Code of Australia |
|------------------------------------|--|----------------------------|
| Fire shutters | AS 1905.2 (fire resistant roller shutters) | Spec C3.4 |
| Smoke detectors and heat detectors | AS 3786 -- 1993 amdt 4, Jan 2004 | Spec E2.2a |

Note: All existing and proposed fire safety measures are to be assessed annually and a copy referred to the relevant local council and to the NSW Fire Brigades. The Annual Fire Safety Statement is to be prominently displayed in each building.

3/28 Reddall Street
MANLY

17-Oct-12
CC2013-00368

