

## Natural Environment Referral Response - Flood

<b>Application Number:</b>	DA2020/1711
<b>Date:</b>	22/02/2021
<b>To:</b>	Rebecca Englund
<b>Land to be developed (Address):</b>	Lot 1 SP 12989 , 1 / 21 - 23 The Corso MANLY NSW 2095 Lot 2 SP 12989 , 2 / 21 - 23 The Corso MANLY NSW 2095 Lot 3 SP 12989 , 3 / 21 - 23 The Corso MANLY NSW 2095 Lot 4 SP 12989 , 4 / 21 - 23 The Corso MANLY NSW 2095 Lot 5 SP 12989 , 5 / 21 - 23 The Corso MANLY NSW 2095 Lot 6 SP 12989 , 6 / 21 - 23 The Corso MANLY NSW 2095 Lot 7 SP 12989 , 7 / 21 - 23 The Corso MANLY NSW 2095 Lot 8 SP 12989 , 8 / 21 - 23 The Corso MANLY NSW 2095 Lot 9 SP 12989 , 9 / 21 - 23 The Corso MANLY NSW 2095 Lot 10 SP 12989 , 10 / 21 - 23 The Corso MANLY NSW 2095 Lot 11 SP 12989 , 11 / 21 - 23 The Corso MANLY NSW 2095 Lot 12 SP 12989 , 12 / 21 - 23 The Corso MANLY NSW 2095 Lot 13 SP 12989 , 13 / 21 - 23 The Corso MANLY NSW 2095 Lot CP SP 12989 , 19 - 23 The Corso MANLY NSW 2095

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The property is not affected by the 1% AEP flood event, but the Market Place entrance is just within the Medium Flood Risk Precinct with a Flood Planning Level of 5.7m AHD.

With a floor level of 6.06m AHD, the proposed alterations are generally above the FPL.

No flood related objections.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Natural Environment Conditions:

Nil.