

## Engineering Referral Response

Application Number:	DA2020/0576
Date:	13/07/2020
To:	Jordan Davies
Land to be developed (Address):	Lot 14 DP 240799 , 13 Kuyora Place NORTH NARRABEEN NSW 2101

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

Council's records indicate that the proposed works is located in the immediate vicinity of Council's stormwater pipeline. As such the asset location will need to be confirmed to undertake an informed assessment on the proposed works. The applicant shall demonstrate compliance with Council's Pittwater 21 DCP B5.12. It is recommended that the applicant provides additional information to accurately locate, confirm dimensions including depth and plot Council's stormwater pipelines and associated infrastructure to scale on the DA plans. This should be carried out by a service locating contractor and registered surveyor. Council has public Planning Maps online with stormwater information as a reference for detailed stormwater investigations, available under the "Stormwater" overlay map (<https://services.northernbeaches.nsw.gov.au/icongis/index.html>).

*Please note that concurrence from Council's Stormwater Engineering section will be required.*

The proposed application cannot be supported by Development Engineering due to lack of information to address:

- *Council's stormwater assets for the development in accordance with clause C6 Building Over or Adjacent to Constructed Council Drainage Easements.*

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Engineering Conditions:**

Nil.