## MESH GROUP PTY LTD



10 POPLAR PLACE PICTON NSW 2571 PH: 0427 366090 ADMIN@MESH-GROUP.COM

MESH GROUP P/L

Northern Beaches Council 725 Pittwater Road Dee Why NSW 2099  $27^{\text{th}}$  July , 2020.

Attn Stormwater Engineering

## Dear Sir DRAINS MODEL STORMWATER DISCHARGE FOR PROPOSED DEVELOPMENT at 28 FISHER ROAD DEE WHY- GEORGE GROUP ARCHITECTS

Please find attached our Drains Model DRN file and Stormwater drawings for the proposed development for your information and approval.

This model has been prepared by a Civil Engineer and we are happy to provide Certification of same if required by Council.

The model has been prepared in accordance with Northern Beaches Council Stormwater Management Policy and Australian Standards Requirements.

## Site Information.

Site comprises of 2 properties 9 Francis Street and 28 Fisher Road Dee Why

• 9 Francis Street Surveyed area = 695.6 m2

• 28 Fisher Road Surveyed area = 695.6 m2

The site has a fall from Francis Street at 29.450 AHD on the west towards Fisher Road at approx.

25.400 AHD. There is approximately 4 metres fall across the site from West to East.

We trust the foregoing meets with your approval and should you require any additional information please contact the undersigned.

Yours Faithfully

1

Jim Gorringe Director – Hydraulic & Fire Services Mob 0427 366090