
Sent: 10/02/2017 10:00:29 PM
Subject: Application No. PP0005/16 - Preliminary Notification of a Draft Planning Proposal (Rezoning) for 6 Jacksons Road and 10 and 12 Boondah Road, Warriewood
Attachments: Letter Out - PP000516 - Preliminary Notification of Draft Planning Proposal - Rezoning - 6 Jacksons Road and 10 and 12 Boondah Road Warriewood - Northern Beaches Council.pdf; Letter Out - PP000516 - Preliminary Notification of Draft Planning Proposal - Rezoning - 6 Jacksons Road and 10 and 12 Boondah Road Warriewood - Northern Beaches Council.pdf;

Attention: Land Release Team

Please find attached FRNSW comments in response to your letter dated 20 January 2017 for the above proposal.

Kind Regards,

Jamie Vistnes
Manager
Fire Safety Policy Unit



E Jamie.Vistnes@fire.nsw.gov.au | **T** (02) 9742 7309 | **M** 0408 877 479 | **F** (02) 9742 7483 |
www.fire.nsw.gov.au
Amarina Avenue, Greenacre NSW 2190 | Locked Bag 12, Greenacre NSW 2190

[Twitter.com/FireRescueNSW](https://twitter.com/FireRescueNSW) | [Facebook.com/FRNSW](https://facebook.com/FRNSW) | YouTube.com/FireAndRescueNSW



FRNSW CONFIDENTIALITY NOTICE AND DISCLAIMER

The information in this transmission may be confidential and/or protected by legal professional privilege, and is intended only for the person or persons to whom it is addressed. If you are not the intended recipient of this message you must not read, forward, print, copy, disclose, use or store in any way the information in this e-mail or any attachment it may contain. Please notify the sender immediately and delete or destroy all copies of this e-mail and any attachment it may contain.

Views expressed in the message are those of the individual sender, and are not necessarily the views of Fire & Rescue NSW. Use of electronic mail is subject to FRNSW policy and guidelines. FRNSW reserves the right to filter, inspect, copy, store and disclose the contents of electronic mail messages, as authorised by law.

This message has been scanned for viruses.



Fire & Rescue NSW

File Ref. No: BFS17/178
TRIM Ref. No: D17/8017

Pittwater Council
PO Box 882
Mona Vale NSW 1660
Email: pittwater@northernbeaches.nsw.gov.au

10 February 2017

Attention: Land Release Team

RE: Application No. PP0005/16 - Preliminary Notification of a Draft Planning Proposal (Rezoning) for 6 Jacksons Road and 10 and 12 Boondah Road, Warriewood

Thank you for the opportunity to comment on Application No. PP0005/16 - Preliminary Notification of a Draft Planning Proposal (Rezoning) for 6 Jacksons Road and 10 and 12 Boondah Road Warriewood as per your letter dated 20 January 2017.

FRNSW recommend that Sydney Water, or the relevant water authority for the affected sites, be consulted in order to ensure that adequate water supplies are provided to the town mains which will provide sufficient capacity for fire fighting.

If you require further information in relation to determining what adequate water supplies for fire fighting would be needed, or if you have any other queries, please do not hesitate to contact myself on (02) 9742 7434.

Yours sincerely

Jamie Vistnes
Manager, Fire Safety Policy Unit
Community Safety Directorate





Fire & Rescue NSW

File Ref. No: BFS17/178
TRIM Ref. No: D17/8017

Pittwater Council
PO Box 882
Mona Vale NSW 1660
Email: pittwater@northernbeaches.nsw.gov.au

10 February 2017

Attention: Land Release Team

RE: Application No. PP0005/16 - Preliminary Notification of a Draft Planning Proposal (Rezoning) for 6 Jacksons Road and 10 and 12 Boondah Road, Warriewood

Thank you for the opportunity to comment on Application No. PP0005/16 - Preliminary Notification of a Draft Planning Proposal (Rezoning) for 6 Jacksons Road and 10 and 12 Boondah Road Warriewood as per your letter dated 20 January 2017.

FRNSW recommend that Sydney Water, or the relevant water authority for the affected sites, be consulted in order to ensure that adequate water supplies are provided to the town mains which will provide sufficient capacity for fire fighting.

If you require further information in relation to determining what adequate water supplies for fire fighting would be needed, or if you have any other queries, please do not hesitate to contact myself on (02) 9742 7434.

Yours sincerely

Jamie Vistnes
Manager, Fire Safety Policy Unit
Community Safety Directorate

