



24-28 Campbell St  
Sydney NSW 2000  
All mail to  
GPO Box 4009  
Sydney NSW 2001  
T +61 2 131 525  
ausgrid.com.au

Attention: Annabelle Lindsay of NORTHERN BEACHES COUNCIL

Ausgrid does not have any objections for the proposed development at 1110 BARRENJOEY ROAD PALM BEACH, DA No. 482/98 Mod2020/0164. The applicant/developer should note the following comments below regarding any proposal within the proximity of existing electrical network assets.

### **Overhead Powerlines**

Safework NSW Document – Work Near Overhead Powerlines: Code of Practice, outlines the minimum safety separation requirements between these mains/poles to structures within the development throughout the construction process. It is a statutory requirement that these distances be maintained throughout construction. Special consideration should be given to the positioning and operating of cranes and the location of any scaffolding.

The “as constructed” minimum clearances to the mains should also be considered. These distances are outlined in the Ausgrid Network Standard, NS220 Overhead Design Manual. This document can be sourced from Ausgrid’s website, [www.ausgrid.com.au](http://www.ausgrid.com.au)

It remains the responsibility of the developer and relevant contractors to verify and maintain these clearances onsite.

"Should the existing overhead mains require relocating due to the minimum safety clearances being compromised in either of the above scenarios, this relocation work is generally at the developers cost.

It is also the responsibility of the developer to ensure that the existing overhead mains have sufficient clearance from all types of vehicles that are expected be entering and leaving the site."

### **Underground Cables**

Special care should also be taken to ensure that driveways and any other construction activities within the footpath area do not interfere with the existing cables in the footpath. Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed. Hence it is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area.

Safework Australia – Excavation Code of Practice, and Ausgrid’s Network Standard NS156 outlines the minimum requirements for working around Ausgrid’s underground cables.

Should ground anchors be required in the vicinity of the underground cables, the anchors must not be installed within 300mm of any cable, and the anchors must not pass over the top of any cable.

Kind Regards,

**Michael Lai | Asset Protection Officer | Transmission Services | Ausgrid**

Homebush Depot, Level 1, Bldg 2

Level 1, 25-27 Pomeroy Street, Homebush NSW 2140 AUSTRALIA

| ✉: [development@ausgrid.com.au](mailto:development@ausgrid.com.au) |

Please consider the environment before printing this email