

Building Assessment Referral Response

Application Number:	DA2021/2002
Date:	10/01/2022
To:	Claire Ryan
Land to be developed (Address):	Lot 1 DP 27363 , 615 Warringah Road FORESTVILLE NSW 2087 Lot 1 DP 406001 , 617 Warringah Road FORESTVILLE NSW 2087 Lot X DP 416724 , 617 Warringah Road FORESTVILLE NSW 2087

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

Amended Comments 10/1/2022

The application has been reviewed following the submission of a BCA Report from 360 Certification with regards to matters raised by previous referral comments dated 13/12/2021. There are now no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

Original Comments 13/12/2021

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. In this regard the following report is required to be submitted to Council prior to further consideration:

Building Code of Australia Report

A 'Building Code of Australia (BCA) Assessment Report' / 'Fire Audit Report' from an appropriately qualified Registered Certifier* will need to be submitted for determination.

The report is to detail the extent to which the existing building (relevant affected parts) does or does not comply with the deemed-to satisfy provisions of Sections, D and E of the Building Code of Australia. The report is to also provide recommendations with respect to the existing building / works required to ensure that the specified measures and facilities contained in the existing building, including any modifications to be made by the proposed development are appropriate for its intended use.

*To be regarded as an "appropriately qualified registered certifier" the certifier must hold the relevant level of accreditation that would enable the certifier to issue a construction certificate for the subject building.

The 'Building Code of Australia (BCA) Assessment Report' / 'Fire Audit Report' is to be submitted to the Certifying Authority with the Construction Certificate application.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Building Code of Australia Upgrade requirements and Fire Safety Upgrade

The works and fire upgrading measures to upgrade the building as detailed and recommended in the Building Code of Australia Audit Report prepared by 360 Certification, dated 6/1/2021, Revision 1 are to be considered as part of the assessment of the Construction Certificate. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and the NSW Fire Brigade.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and the NSW Fire Brigade an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.