

## **DEVELOPMENT APPLICATION ASSESSMENT REPORT**

Application Number:	DA2022/1224			
Responsible Officer:	Nick England			
Land to be developed (Address):	Lot 60 DP 21576, 61 Wyadra Avenue NORTH MANLY NSV 2100			
Proposed Development:	Alterations and additions to a dwelling house including a carport			
Zoning:	Warringah LEP2011 - Land zoned R2 Low Density Residential			
Development Permissible:	Yes			
Existing Use Rights:	No			
Consent Authority:	Northern Beaches Council			
Land and Environment Court Action:	: No			
Owner:	Barry Anthony Molony Katherine Molony			
Applicant:	DM Planning Pty Ltd			
Application Lodged:	28/07/2022			
Integrated Development:	No			
Designated Development:	No			
State Reporting Category:	Residential - Alterations and additions			
Notified:	04/08/2022 to 18/08/2022			
Advertised:	Not Advertised			
Submissions Received:	0			
Clause 4.6 Variation:	Nil			
Recommendation:	Approval			
Estimated Cost of Works:	\$ 49,555.00			

## PROPOSED DEVELOPMENT IN DETAIL

The proposed development consists of the alterations and addition to an existing dwelling house, consisting of the demolition of an existing carport (1 vehicle) and the construction of a new 1 vehicle carport and storage area, bin storage and associated landscaping.

## **ASSESSMENT INTRODUCTION**

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

DA2022/1224 Page 1 of 24



- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;
- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral
  to relevant internal and external bodies in accordance with the Act, Regulations and relevant
  Development Control Plan;
- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination);
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

#### SUMMARY OF ASSESSMENT ISSUES

Warringah Local Environmental Plan 2011 - 6.4 Development on sloping land Warringah Development Control Plan - B7 Front Boundary Setbacks Warringah Development Control Plan - C3 Parking Facilities

#### SITE DESCRIPTION

Property Description:	Lot 60 DP 21576 , 61 Wyadra Avenue NORTH MANLY NSW 2100			
Detailed Site Description:	The subject site consists of one (1) allotment located on the northern/ side of Wyadra Avenue, North Manly.			
	The site is regular in shape with a frontage of 15.3m along Wyadra Avenue and a depth of 37/38m. The site has a surveyed area of 576m².			
	The site is located within the R2 Low Density Residential zone of Warringah LEP 2011 and accommodates a two storey dwelling house and attached carport with parking fo one (1) vehicle.			
	The site has a northerly aspect with a moderate slope, steepening on the southern boundary frontage. The ground level of the existing dwelling sits approximately 3m below the adjoining road reserve.			
	The site has minor vegetation with no significant natural features.			
	Adjoining and surrounding development to all boundaries of the subject site are characterised by dwelling houses.			

Мар:

DA2022/1224 Page 2 of 24





## **SITE HISTORY**

A search of Council's records has revealed that there are no recent or relevant applications for this site.

The land has been used for residential purposes for an extended period of time.

# **ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)**

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

Section 4.15 Matters for Consideration	Comments		
Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument	See discussion on "Environmental Planning Instruments" in this report.		
Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument	There are no current draft environmental planning instruments.		
Section 4.15 (1) (a)(iii) – Provisions of any development control plan	Warringah Development Control Plan applies to this proposal.		
Section 4.15 (1) (a)(iiia) – Provisions of any planning agreement	None applicable.		
Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2021 (EP&A Regulation 2021)	Clause 88(1) of the EP&A Regulation 2021 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent.		
	Clause 29 of the EP&A Regulation 2021 requires the submission of a design verification certificate from the building designer at lodgement of the development application. This clause is not relevant to this application.		
	Clauses 36 of the EP&A Regulation 2021 allow Council to		

DA2022/1224 Page 3 of 24



Section 4.15 Matters for Consideration	Comments
	request additional information. No additional information was requested in this case.
	Clause 61 of the EP&A Regulation 2021 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent.
	Clauses 62and/or 64 of the EP&A Regulation 2021 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This clause is not relevant to this application.
	Clause 98 of the EP&A Regulation 2021 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This matter has been addressed via a condition of consent.
	Clause 69 of the EP&A Regulation 2021 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.
Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social and economic impacts in the locality	(i) <b>Environmental Impact</b> The environmental impacts of the proposed development on the natural and built environment are addressed under the Warringah Development Control Plan section in this report.
	(ii) <b>Social Impact</b> The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.
	(iii) <b>Economic Impact</b> The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.
Section 4.15 (1) (c) – the suitability of the site for the development	The site is considered suitable for the proposed development.
Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs	See discussion on "Notification & Submissions Received" in this report.
Section 4.15 (1) (e) – the public interest	No matters have arisen in this assessment that would justify the refusal of the application in the public interest.

# **EXISTING USE RIGHTS**

Existing Use Rights are not applicable to this application.

DA2022/1224 Page 4 of 24



#### **BUSHFIRE PRONE LAND**

The site is not classified as bush fire prone land.

#### **NOTIFICATION & SUBMISSIONS RECEIVED**

The subject development application has been publicly exhibited from 04/08/2022 to 18/08/2022 in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2021 and the Community Participation Plan.

As a result of the public exhibition of the application Council received no submissions.

## **REFERRALS**

Internal Referral Body	Comments
Landscape Officer	The development application is for alterations and additions to the existing dwelling, a new carport and driveway, and associated works, as described and illustrated in the reports and plans.
	The application is assessed by Landscape Referral against Warringah Local Environmental Plan 2011 and the following Warringah Development Control Plan 2011 controls (but not limited to):  • D1 Landscaped Open Space and Bushland Setting  • E1 Preservation of Trees or Bushland Vegetation
	An Arboricultural Impact Assessment (AIA) is included in the application and will be assessed as part of the Landscape Referral. It is noted tree 1 is required to be removed and is located in the road reserve. Tree 1 is a <i>Livistona australis</i> and only a small representation of the species which is viable for transplantation. Should the development application be approved, a Transplanting Methodology Plan shall be prepared by a qualified Arborist, and tree 1 transplanted to a suitable location within the front setback, subject to the imposed conditions. Tree 3 and tree 4 offer a buffer to the neighbouring property which will lessen the visual impact of the proposed elevated carport, therefore both trees shall be retained. The elevated carport shall be structurally designed in consultation with the Arborist to ensure the retention of both tree 3 and 4, subject to the imposed conditions. No level changes within the tree protection zone of tree 2 are permissible unless instructed by the Project Arborist.
	A deciduous tree, adjacent to the existing pedestrian entry path, has not been assessed in the AIA and will suffer a major encroachment by the proposed driveway. No information has been provided, therefore it has been assessed that this tree will be removed to facilitate the works. To offset any canopy loss a locally native replacement tree shall be installed within the property boundary, subject to the imposed conditions. All trees to be retained shall be protected in accordance with the conditions of consent.
	No Landscape Plan is included in the application. The road level sits higher than the proposed carport; however, to lessen the visual

DA2022/1224 Page 5 of 24



Internal Referral Body	Comments		
	impact to the street screen planting shall be installed along the southern boundary, subject to the imposed conditions. A terraced landscape garden is proposed and only shown indicatively, and as such any new planting shall be installed in accordance with the conditions of consent.  Landscape Referral notes that work is proposed in the road reserve which have not been assessed as part of this referral. The appropriate referral body shall be consulted on this matter.		
NECC (Development Engineering)	The proposed driveway crossing is acceptable subject to conditions. Stormwater is to be in accordance with Council's Water Management for Development Policy.  The proposed new stairs in the road reserve are to be assessed by Council's Road Asset Team.		
	Development Engineering support the proposal, subject to conditions as recommended.		

External Referral Body	Comments
	The proposal was referred to Ausgrid who provided a response stating that the proposal is acceptable subject to compliance with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice. These recommendations will be included as a condition of consent.

## **ENVIRONMENTAL PLANNING INSTRUMENTS (EPIs)\***

All, Environmental Planning Instruments (SEPPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

# State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

#### SEPP (Transport and Infrastructure) 2021

## Ausgrid

Section 2.48 of Chapter 2 requires the Consent Authority to consider any development application (or an application for modification of consent) for any development carried out:

• within or immediately adjacent to an easement for electricity purposes (whether or not the electricity infrastructure exists).

DA2022/1224 Page 6 of 24



- immediately adjacent to an electricity substation.
- within 5.0m of an overhead power line.
- includes installation of a swimming pool any part of which is: within 30m of a structure supporting an overhead electricity transmission line and/or within 5.0m of an overhead electricity power line.

<u>Comment:</u> The proposal was referred to Ausgrid who raised no objections, subject to conditions which have been included in the recommendation of this report.

## SEPP (Resilience and Hazards) 2021

#### Chapter 4 - Remediation of Land

Sub-section 4.6 (1)(a) of Chapter 4 requires the Consent Authority to consider whether land is contaminated. Council records indicate that the subject site has been used for residential purposes for a significant period of time with no prior land uses. In this regard it is considered that the site poses no risk of contamination and therefore, no further consideration is required under sub-section 4.6 (1)(b) and (c) of this Chapter and the land is considered to be suitable for the residential land use.

## Warringah Local Environmental Plan 2011

Is the development permissible?	Yes	
After consideration of the merits of the proposal, is the development consistent with:		
aims of the LEP?	Yes	
zone objectives of the LEP?	Yes	

Principal Development Standards

Standard	Requirement	Proposed	% Variation	Complies
Height of Buildings:	8.5m	3.9m	N/A	Yes

Compliance Assessment

Clause	Compliance with Requirements
4.3 Height of buildings	Yes
6.2 Earthworks	Yes
6.4 Development on sloping land	Yes

#### **Detailed Assessment**

#### 6.4 Development on sloping land

Under this clause, development consent must not be granted to development on land to which this clause applies unless the consent authority is satisfied that:

(a) the application for development has been assessed for the risk associated with landslides in

DA2022/1224 Page 7 of 24



## relation to both property and life, and

<u>Comment</u>: The applicant has submitted a Geotechnical Assessment Report prepared by a suitably qualified geotechnical expert. This report concludes that the proposed development is acceptable from a geotechnical perspective and therefore, Council is satisfied that the development has been assessed for the risk associated with landslides in relation to both property and life.

(b) the development will not cause significant detrimental impacts because of stormwater discharge from the development site, and

<u>Comment</u>: The applicant has submitted a Geotechnical Assessment Report prepared by a suitably qualified geotechnical expert. This report concludes that the proposed development is acceptable from a geotechnical perspective. The application has also been assessed by Council's Development Engineers in relation to stormwater. The Engineers have raised no objections to approval, subject to conditions. Therefore, Council is satisfied that the development will not cause significant detrimental impacts because of stormwater discharge from the development site.

(c) the development will not impact on or affect the existing subsurface flow conditions.

<u>Comment</u>: The applicant has submitted a Geotechnical Assessment Report prepared by a suitably qualified geotechnical expert. This report concludes that the proposed development is acceptable from a geotechnical perspective. The application has also been assessed by Council's Development Engineers in relation to stormwater. The Engineers have raised no objections to approval, subject to conditions. Therefore, Council is satisfied that the development will not result in adverse impacts or effects on the existing subsurface flow conditions.

#### **Warringah Development Control Plan**

#### **Built Form Controls**

Built Form Control	Requirement	Proposed	% Variation*	Complies
B1 Wall height	7.2m	3.8m (east elevation)	N/A	Yes
B3 Side Boundary Envelope	5m (east)	No breach	N/A	Yes
	5m (west)	No breach	N/A	Yes
B5 Side Boundary Setbacks	0.9m (east)	2.2m	N/A	Yes
	0.9m (west)	7.2m	N/A	Yes
B7 Front Boundary Setbacks	6.5m	2.1m	68%	No
B9 Rear Boundary Setbacks	6m	N/A	N/A	N/A
D1 Landscaped Open Space (LOS) and Bushland Setting	40%	257m <sup>2</sup> or 44%	N/A	Yes

#### Compliance Assessment

	<u>-</u>	Consistency Aims/Objectives
A.5 Objectives	Yes	Yes
B1 Wall Heights	Yes	Yes

DA2022/1224 Page 8 of 24



Clause	Compliance with Requirements	Consistency Aims/Objectives
B3 Side Boundary Envelope	Yes	Yes
B5 Side Boundary Setbacks	Yes	Yes
B7 Front Boundary Setbacks	No	Yes
C2 Traffic, Access and Safety	Yes	Yes
C3 Parking Facilities	No	Yes
C4 Stormwater	Yes	Yes
C7 Excavation and Landfill	Yes	Yes
C8 Demolition and Construction	Yes	Yes
C9 Waste Management	Yes	Yes
D1 Landscaped Open Space and Bushland Setting	Yes	Yes
D2 Private Open Space	Yes	Yes
D6 Access to Sunlight	Yes	Yes
D7 Views	Yes	Yes
D8 Privacy	Yes	Yes
D9 Building Bulk	Yes	Yes
D10 Building Colours and Materials	Yes	Yes
D11 Roofs	Yes	Yes
D12 Glare and Reflection	Yes	Yes
D20 Safety and Security	Yes	Yes
D21 Provision and Location of Utility Services	Yes	Yes
E1 Preservation of Trees or Bushland Vegetation	Yes	Yes
E10 Landslip Risk	Yes	Yes

## **Detailed Assessment**

## **B7 Front Boundary Setbacks**

## **Description of non-compliance**

The proposed carport is located 2.1m from the front (southern) boundary of the site, which is a 68% variation with the minimum requirement.

### Merit consideration:

With regard to the consideration for a variation, the development is considered against the underlying Objectives of the Control as follows:

To create a sense of openness.

<u>Comment:</u> The topography of the site, which falls down sharply from the road reserve, has the effect of minimising the visibility of any structures when viewed from the public domain. Hence, despite the proposed structure being at a relatively close distance to the boundary, its visibility is mitigated, which in turn serves this objective.

DA2022/1224 Page 9 of 24



• To maintain the visual continuity and pattern of buildings and landscape elements.

<u>Comment:</u> The established streetscape of Wyandra Avenue is such that there are numerous instances of parking structures forward of the front boundary on the northern side of Wyadra Avenue. Despite this, it is however considered that the proposed development still provides a substantive setback from the front boundary (between 2.1 and 2.7m) which permits an adequate area for a sufficent amount of landscaping at the frontage that will readily meet this objective.

To protect and enhance the visual quality of streetscapes and public spaces.

<u>Comment:</u> The topography of the site assists in minimising the visibility of the structure from the Wyadra Avenue frontage and also utilises adequate areas of landscaped open space to further minimise its visual impact from surrounding areas. Therefore, this objective is achieved.

To achieve reasonable view sharing.

<u>Comment:</u> There is unlikely to be any loss of any substantive views enjoyed from surrounding properties, as result of the proposed non-compliance

Having regard to the above assessment, it is concluded that the proposed development is consistent with the relevant objectives of WDCP 2011 and the objectives specified in s1.3 of the Environmental Planning and Assessment Act, 1979. Accordingly, this assessment finds that the proposal is supported, in this particular circumstance.

## C3 Parking Facilities

Part C3 Parking Facilities / Appendix 1 Car Parking Requirements of the WDCP 2011 requires that at least two (2) car spaces be provided for a dwelling house. The proposed development currently has an existing provision of one (1) car parking space, within the existing carport.

As the proposal does not involve any additional floor space, or any other intensification of the existing dwelling, the on going retention of 1 designated car space is considered acceptable. In effect, the proposal will involve the re-location of the existing car space provision and involve no loss in the existing services on the site. Hence, despite the numerical non-compliance, the proposed development is considered to achieve the objectives of the control and full compliance with the standard is not considered necessary under the circumstances.

## THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly affect threatened species, populations or ecological communities, or their habitats.

## **CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN**

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

### **POLICY CONTROLS**

## Northern Beaches Section 7.12 Contributions Plan 2022

DA2022/1224 Page 10 of 24



As the estimated cost of works is less than \$100,001.00 the policy is not applicable to the assessment of this application.

#### CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2021;
- All relevant and draft Environmental Planning Instruments;
- Warringah Local Environment Plan;
- Warringah Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

#### **RECOMMENDATION**

THAT Council as the consent authority grant Development Consent to DA2022/1224 for Alterations and additions to a dwelling house including a carport on land at Lot 60 DP 21576, 61 Wyadra Avenue, NORTH MANLY, subject to the conditions printed below:

## **DEVELOPMENT CONSENT OPERATIONAL CONDITIONS**

## 1. Approved Plans and Supporting Documentation

The development must be carried out in compliance with the endorsed stamped plans and documentation listed below, except as amended by any other condition of consent:

a) Approved Plans

Architectural Plans - Endorsed with Council's stamp		
Drawing No.	Dated	Prepared By
Drawing No.	Datea	r repared by

DA2022/1224 Page 11 of 24



AR DA 1-00 Revision B	24 May 2022	Nikki Mote Architect
AR DA 1-01 Revision B	24 May 2022	Nikki Mote Architect
AR DA 1-02 Revision B	24 May 2022	Nikki Mote Architect
AR DA 3-00 Revision B	24 May 2022	Nikki Mote Architect
AR DA 4-00 Revision B	24 May 2022	Nikki Mote Architect
AR DA 5-00 Revision B	24 May 2022	Nikki Mote Architect
AR DA 5-01 Revision B	24 May 2022	Nikki Mote Architect

Engineering Plans		
Drawing No.	Dated	Prepared By
2022-004-C1 Revision A	June 2022	BURGESS, ARNOTT & GRAVA PTY. LTD.
2022-004-H1 Revision A	July 2022	BURGESS, ARNOTT & GRAVA PTY. LTD.

Reports / Documentation – All recommendations and requirements contained within:		
Report Title / No.	Dated	Prepared By
Preliminary Geotechnical Assessment No.J3580A	20 July 2021	White Geotechnical Group

- b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.
- c) The development is to be undertaken generally in accordance with the following:

Waste Management Plan		
Drawing No/Title.	Dated	Prepared By
-	29 June 2022	Nikki Mote

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

# 2. Compliance with Other Department, Authority or Service Requirements

The development must be carried out in compliance with all recommendations and requirements, excluding general advice, within the following:

Other Department, Authority or Service	EDMS Reference	Dated
Ausgrid	Ausgrid Referral Response	12 August 2022

(NOTE: For a copy of the above referenced document/s, please see Application Tracking on Council's website <a href="https://www.northernbeaches.nsw.gov.au">www.northernbeaches.nsw.gov.au</a>)

Reason: To ensure the work is carried out in accordance with the determination and the statutory requirements of other departments, authorities or bodies.

DA2022/1224 Page 12 of 24



#### 3. Prescribed Conditions

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
  - (i) showing the name, address and telephone number of the Principal Certifier for the work, and
  - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
  - (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifier for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
  - (i) in the case of work for which a principal contractor is required to be appointed:
    - A. the name and licence number of the principal contractor, and
    - B. the name of the insurer by which the work is insured under Part 6 of that Act,
  - (ii) in the case of work to be done by an owner-builder:
    - A. the name of the owner-builder, and
    - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifier for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
  - (i) protect and support the adjoining premises from possible damage from the excavation, and
  - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
  - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
  - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

DA2022/1224 Page 13 of 24



In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative requirement.

### 4. General Requirements

(a) Unless authorised by Council:Building construction and delivery of material hours are restricted to:

- 7.00 am to 5.00 pm inclusive Monday to Friday,
- 8.00 am to 1.00 pm inclusive on Saturday,
- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

• 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) Should any asbestos be uncovered on site, its demolition and removal must be carried out in accordance with WorkCover requirements and the relevant Australian Standards.
- (c) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of an Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (d) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (e) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (f) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No skip bins, building materials, demolition or excavation waste of any nature, and no hoist, plant or machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (j) No trees or native shrubs or understorey vegetation on public property (footpaths,

DA2022/1224 Page 14 of 24



roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.

- (k) Prior to the commencement of any development onsite for:
  - i) Building/s that are to be erected
  - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
  - iii) Building/s that are to be demolished
  - iv) For any work/s that is to be carried out
  - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

- (I) A "Road Opening Permit" must be obtained from Council, and all appropriate charges paid, prior to commencement of any work on Council property. The owner/applicant shall be responsible for all public utilities and services in the area of the work, shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.
- (m) The works must comply with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice.
- (n) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
  - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2018
- (iv) Australian Standard AS1926 Swimming Pool Safety
- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.

DA2022/1224 Page 15 of 24



Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

## FEES / CHARGES / CONTRIBUTIONS

## 5. Security Bond

A bond (determined from cost of works) of \$2,000 and an inspection fee in accordance with Council's Fees and Charges paid as security are required to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, and details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is located on Council's website at www.northernbeaches.nsw.gov.au).

Reason: To ensure adequate protection of Council's infrastructure.

# CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### 6. Footing Design Near Trees to be Retained

Footing structural layout plans for the elevated carport shall be developed in co-ordination with an Arborist with AQF minimum Level 5 qualifications in arboriculture, and a qualified Structural Engineer, following a tree root mapping investigation near existing tree(s) identified in the Arboricultural Impact Assessment as tree numbers 3 and 4, to locate critical tree roots and recommend footing locations for the construction of the elevated carport. The Arborist shall review, comment, recommend design revision as required and approve the footing layout, to ensure the locations of footings will be manageable in terms of tree protection measures.

A non-destructive root investigation shall be conducted complying with clause 3.3.4 of AS 4970-2009 Protection of Trees on Development Sites.

The Arborist shall submit certification to the Certifying Authority, that the locations of the footings are accepted. The agreed footing structural layout plans shall be submitted to the Certifying Authority for approval prior to the issue of a Construction Certificate.

Reason: Tree protection.

#### 7. Transplanting Methodology Plan

DA2022/1224 Page 16 of 24



A Transplanting Methodology Plan, prepared by an Arborist with AQF minimum Level 5 qualifications in arboriculture, shall be documented to demonstrate the requirement for transplanting tree 1 (*Livistona australis*) to an appropriate location within the front setback, including:

- i) Preparation of the transplantation site,
- ii) Preparation of the trees/palms to be transplanted,
- iii) transplanting methodology and installation works,
- iv) post-transplanting care and duration,
- v) ongoing maintenance program,
- vi) replacement strategy if transplanting fails in the long term.

The transplanting location shall be at least 3.0 metres from buildings, 2.0 metres from structures, and at least 1.5 metres from common boundaries.

The Transplanting Methodology is to be submitted to the Certifying Authority for approval prior to issue of a Construction Certificate

Reason: Tree protection.

## 8. Stormwater Disposal from Low Level Property

The applicant is to demonstrate how stormwater from the new development within this consent shall be disposed of to an existing approved system or in accordance with Northern Beaches Council's Water Management for Development Policy in particular Section 5.5 Stormwater Drainage from Low Level Properties. Details demonstrating that the existing approved system can accommodate the additional flows or compliance with the Northern Beaches Council's Water Management for Development Policy are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from the development.

### 9. Elevated Parking Facility Design

The Applicant is to provide structural engineering plans including specifications and details by a suitably qualified Structural Engineer for the elevated parking facility in accordance with the provisions of Australian/New Zealand Standard AS/NZS 2890.1:2004 parking facilities - Offstreet car parking Section 2.4.5 Physical controls.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Safety and Compliance with this consent.

## 10. Submission Roads Act Application for Civil Works in the Public Road

The Applicant is to submit an Infrastructure Works on Council Roadway application to Council. Engineering plans for the driveway works within the road reserve are to be submitted to Council for approval under the provisions of Sections 138 and 139 of the Roads Act 1993.

The application is to include Civil Engineering plans for the design of the driveway which are to be generally in accordance with the Council's Standard Vehicle Crossing Profile. The plan shall be prepared by a qualified Civil/Structural Engineer.

The design must include the following information:

1. A barrier wall on either side of the crossing where the finished driveway level exceeds

DA2022/1224 Page 17 of 24



- 600mm to the natural ground level in accordance with the requirements of Section 2.4.5 of AS/NZS 2890.1:2004.
- 2. The above barrier walls are to be a minimum of 1.5 metres off the kerb alignment.
- 3. The above barrier walls are to be designed to ensure the sight lines for vehicles entering and exiting the driveway comply with the requirements of Section 3.2.4 of AS/NZS 2890.1:2004.

The fee associated with the assessment and approval of the application is to be in accordance with Council's Fee and Charges.

An approval is to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure engineering works are constructed in accordance with relevant standards and Council's specification.

## 11. Structural Adequacy and Excavation Work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

## 12. Compliance with Standards

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Principal Certifier prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

## CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

# 13. **Project Arborist**

A Project Arborist with minimum AQF Level 5 in arboriculture shall be engaged to provide tree protection measures in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites.

The Project Arborist shall be in attendance and supervise all works in tree protection zones, and in particular:

- i) the installation of tree protection measures for all trees to be retained,
- ii) all relevant hold points outlined in the Transplanting Methodology Plan,
- iii) additionally, the Project Arborist shall be in attendance and supervise any landscaping works within the TPZ of all existing trees to be retained.

DA2022/1224 Page 18 of 24



Existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by the Project Arborist.

All tree protection measures specified must:

- a) be in place before work commences on the site, and
- b) be maintained in good condition during the construction period, and
- c) remain in place for the duration of the construction works.

The Project Arborist shall provide certification to the Certifying Authority that all recommendations listed for the protection of the existing tree(s) have been carried out satisfactorily to ensure no impact to the health of the tree(s). Photographic documentation of the condition of all trees to be retained shall be recorded, including at commencement, during the works and at completion.

#### Note:

- i) A separate permit or development consent may be required if the branches or roots of a protected tree on the site or on an adjoining site are required to be pruned or removed.
- ii) Any potential impact to trees as assessed by the Project Arborist will require redesign of any approved component to ensure existing trees upon the subject site and adjoining properties are preserved and shall be the subject of a modification application where applicable.

Reason: Tree protection.

## CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

#### 14. Protection of Existing Street Trees

All existing street trees in the vicinity of the works shall be retained during all construction stages, and the street tree fronting the development site shall be protected by tree protection fencing in accordance with Section 4 of Australian Standard 4970-2009 Protection of Trees on Development Sites.

All street trees within the road verge are protected under Northern Beaches Council development control plans, except where Council's written consent for removal has been obtained. The felling, lopping, topping, ringbarking, or removal of any tree(s) is prohibited.

No excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of street trees.

Should any problems arise with regard to the existing or proposed trees on public land during construction, Council's Tree Services section is to be contacted immediately to resolve the matter to Council's satisfaction and at the cost of the applicant.

Reason: Street tree protection.

## 15. Tree and Vegetation Protection

- a) Existing trees and vegetation shall be retained and protected, including:
- i) all trees and vegetation within the site, excluding exempt trees and vegetation under the relevant planning instruments of legislation,
- ii) all trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation.
- b) Tree protection shall be undertaken as follows:

DA2022/1224 Page 19 of 24



- i) tree protection shall be in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites, including the provision of temporary fencing to protect existing trees within 5 metres of development,
- ii) existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by an Arborist with minimum AQF Level 5 in arboriculture, iii) removal of existing tree roots at or >25mm (Ø) diameter is not permitted without consultation with an Arborist with minimum AQF Level 5 in arboriculture,
- iv) no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- v) structures are to bridge tree roots at or >25mm ( $\emptyset$ ) diameter unless directed by an Arborist with minimum AQF Level 5 in arboriculture on site,
- vi) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with an Arborist with minimum AQF Level 5 in arboriculture including advice on root protection measures,
- vii) should either or all of v) or vi) occur during site establishment and construction works, an Arborist with minimum AQF Level 5 in arboriculture shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority.
- viii) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of Australian Standard 4970-2009 Protection of Trees on Development Sites,
- ix) tree pruning from within the site to enable approved works shall not exceed 10% of any tree canopy, and shall be in accordance with Australian Standard 4373-2007 Pruning of Amenity Trees, and should additional pruning be required an application to Council's Tree Services shall be submitted for approval or otherwise.

The Certifying Authority must ensure that:

c) The activities listed in section 4.2 of Australian Standard 4970-2009 Protection of Trees on Development Sites, do not occur within the tree protection zone of any tree, and any temporary access to, or location of scaffolding within the tree protection zone of a protected tree, or any other tree to be retained on the site during the construction, is undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of that standard.

Reason: Tree and vegetation protection.

## 16. Road Reserve

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

## 17. Removing, Handling and Disposing of Asbestos

Any asbestos material arising from the demolition process shall be removed and disposed of in accordance with the following requirements:

- Work Health and Safety Act;
- Work Health and Safety Regulation;
- Code of Practice for the Safe Removal of Asbestos [NOHSC:2002 (1998)];
- Guide to the Control of Asbestos Hazards in Buildings and Structures [NOHSC: 3002 (1998).
- Clause 42 of the Protection of the Environment Operations (Waste) Regulation 2005;
- o The demolition must be undertaken in accordance with Australian Standard AS2601 -

DA2022/1224 Page 20 of 24



The Demolition of Structures.

Reason: For the protection of the environment and human health.

#### 18. **Demolition Works - Asbestos**

Demolition works must be carried out in compliance with WorkCover Short Guide to Working with Asbestos Cement and Australian Standard AS 2601 2001 The Demolition of Structures.

The site must be provided with a sign containing the words DANGER ASBESTOS REMOVAL IN PROGRESS measuring not less than 400 mm x 300 mm and be erected in a prominent visible position on the site. The sign is to be erected prior to demolition work commencing and is to remain in place until such time as all asbestos cement has been removed from the site and disposed to a lawful waste disposal facility.

All asbestos laden waste, including flat, corrugated or profiled asbestos cement sheets must be disposed of at a lawful waste disposal facility. Upon completion of tipping operations the applicant must lodge to the Principal Certifier, all receipts issued by the receiving tip as evidence of proper disposal.

Adjoining property owners are to be given at least seven (7) days' notice in writing of the intention to disturb and remove asbestos from the development site.

Reason: To ensure the long term health of workers on site and occupants of the building is not put at risk unnecessarily.

#### 19. Survey Certificate

A survey certificate prepared by a Registered Surveyor is to be provided demonstrating all perimeter walls columns and or other structural elements, floor levels and the finished roof/ridge height are in accordance with the approved plans.

Details demonstrating compliance are to be submitted to the Principal Certifier when the external structure of the building is complete.

Reason: To demonstrate the proposal complies with the approved plans.

### 20. Installation and Maintenance of Sediment Control

Prior to any works commencing on site, including demolition, sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

## 21. Vehicle Crossings

The Applicant is to construct one vehicle crossing 3.65 metres wide in accordance with Northern Beaches Council Drawing No A4-3330/5 EL and the Infrastructure Works on Council Roadway application approval. An Authorised Vehicle Crossing Contractor shall construct the vehicle crossing and associated works within the road reserve in plain concrete. All redundant laybacks

DA2022/1224 Page 21 of 24



and crossings are to be restored to kerb and grass. Prior to the pouring of concrete, the vehicle crossing is to be inspected by Council and a satisfactory "Vehicle Crossing Inspection" card issued.

A copy of the vehicle crossing inspection form is to be submitted to the Principal Certifying Authority.

Reason: To facilitate suitable vehicular access to private property.

## 22. Waste Management During Development

The reuse, recycling or disposal of waste during works must be done generally in accordance with the Waste Management Plan for this development.

Details demonstrating compliance must be submitted to the Principal Certifier.

Reason: To ensure demolition and construction waste is recycled or reused and to limit landfill.

# CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

## 23. Required Tree Planting

One (1) locally native tree shall be planted within the property boundary to achieve at least 6 metres height at maturity, and shall be selected from Northern Beaches Council's Native Plant Species Guide - Curl Curl Ward, or Council's Tree Guide, and in accordance with the following: i) tree planting shall be a minimum planting size of 75 litres, and shall meet the requirements of Natspec - Specifying Trees,

- ii) planted into a prepared planting hole 1m x 1m x 600mm depth, backfilled with a sandy loam mix or approved similar, mulched to 75mm depth minimum and maintained, and watered until established, and shall be located at least 3.0 metres from buildings and other trees, and at least 1.5 metres from common boundaries, and located either within garden bed or within a prepared bed within lawn.
- iii) tree planting shall be positioned in locations to minimise significant impacts on neighbours in terms of blocking winter sunlight to living rooms, private open space and where the proposed location of trees may otherwise be positioned to minimise any significant loss of views from neighbouring and nearby dwellings and from public spaces.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Occupation Certificate.

Reason: To maintain environmental amenity.

# 24. Required Screen Planting

Screen planting shall be installed in accordance with the following:

- i) along the southern boundary, from the eastern boundary junction to the proposed bin storage area
- ii) be a suitable pot size so that plant height is at least 1.5 metres at installation.

The selected planting is to comprise of species capable of attaining a height of 3 metres at maturity.

Plants are to be installed at minimum 1 plant per metre square and in a garden bed prepared with a suitable free draining soil mix and minimum 50mm depth of mulch.

DA2022/1224 Page 22 of 24



Reason: To maintain environmental amenity.

## 25. Landscape Completion

Landscaping is only shown indicatively; however, all planting (including the terraced gardens) shall be implemented in accordance with the following conditions:

i) mass planting shall be installed at minimum 1 plant per metre square for shrubs of a minimum 200mm container size at planting or as otherwise scheduled if greater in size, and at least 4 plants per metre square for grasses/groundcovers of a minimum 140mm container size at planting or as otherwise scheduled if greater in size, and shall be in a garden bed prepared with a suitable free draining soil mix and minimum 50mm depth of mulch,

Prior to the issue of an Occupation Certificate, details shall be submitted to the Certifying Authority, certifying that the landscape works have been completed in accordance with any conditions of consent.

The landscape works under the development application is permitted only within the legal property boundaries, and the proposed landscape works within the road verge shall be part of a Works within the Road Reserve application under section 138 and 139 of the Roads Act, for approval or otherwise.

Reason: Environmental amenity.

## 26. Condition of Retained Vegetation - Project Arborist

Prior to the issue of an Occupation Certificate, a report prepared by the Project Arborist shall be submitted to the Certifying Authority, assessing the health and impact on all existing trees required to be retained, including the following information:

- i) compliance to any Arborist recommendations for tree protection generally and during excavation works,
- ii) extent of damage sustained by vegetation as a result of the construction works,
- iii) any subsequent remedial works required to ensure the long term retention of the vegetation.

Reason: Tree protection.

## 27. Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

## 28. Certification Elevated Parking Facility Work

The Applicant shall submit a Structural Engineers' certificate certifying that the elevated parking facility was constructed in accordance with this development consent and the provisions of Australian/New Zealand Standard AS/NZS 2890.1:2004 parking facilities - Off-street car parking, in particular Section 2.4.5 Physical controls.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

DA2022/1224 Page 23 of 24



Reason: Safety and Compliance with this consent.

## 29. Removal of All Temporary Structures/Material and Construction Rubbish

Once construction has been completed all silt and sediment fences, silt, rubbish, building debris, straw bales and temporary fences are to be removed from the site.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of an Occupation Certificate.

Reason: To ensure bushland management.

# ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

## 30. Landscape Maintenance

If any landscape materials/components or planting under this consent fails, they are to be replaced with similar materials/components. Trees, shrubs and groundcovers required to be planted under this consent are to be mulched, watered and fertilised as required at the time of planting.

If any tree, shrub or groundcover required to be planted under this consent fails, they are to be replaced with similar species to maintain the landscape theme and be generally in accordance with any conditions of consent.

All weeds are to be removed and controlled in accordance with the NSW Biosecurity Act 2015.

Reason: To maintain local environmental amenity.

In signing this report, I declare that I do not have a Conflict of Interest.

## Signed



Nick England, Planner

The application is determined on 07/09/2022, under the delegated authority of:

an

Adam Richardson, Manager Development Assessments

DA2022/1224 Page 24 of 24