

## Building Assessment Referral Response

<b>Application Number:</b>	DA2023/0375
<b>Proposed Development:</b>	Construction of an industrial training facility
<b>Date:</b>	26/04/2023
<b>To:</b>	Stephanie Gelder
<b>Land to be developed (Address):</b>	Lot 1 DP 416586 , 2 Bloodwood Road INGLESIDE NSW 2101

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

#### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Access & Egress**

The proposed building work is required to comply with Part D of the Building Code of Australia. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for building occupant safety.

### Construction in Bush Fire Prone Areas

The recommendations made in the Bush Fire Assessment Report prepared by Building Code & Bushfire Hazard Solutions Pty. Ltd., dated 18/3/2023, Report Ref No. 230667 are to be carried out in full to the building.

Details demonstrating implementation and compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate.

Reason: To ensure adequate provision is made for the design and construction of the building to reduce the risk of ignition from a bushfire and provide building occupant safety