

## Parks, Reserves and Foreshores Referral Response

<b>Application Number:</b>	DA2022/0380
<b>Date:</b>	02/05/2022
<b>To:</b>	Brittany Harrison
<b>Land to be developed (Address):</b>	Lot CP SP 4658 , 10 Kalinya Street NEWPORT NSW 2106 Lot CP SP 4658 , 10 Kalinya Street NEWPORT NSW 2106

### Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore  
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

### Officer comments

The development application is for alterations and refurbishment to an existing swimming pool.

The property adjoins Pittwater waterway downslope. All development works must ensure that surface sediment runoff and/or erosion is controlled, managed and contained within the site boundaries and prevented from travelling across the boundary and into the Pittwater waterway, as conditioned by Riparian Lands and Creeks.

No physical encroachments over the site boundaries are permitted, and structures and built elements are not permitted beyond the site boundaries. Public access to the waterway is not impacted by the proposed development and the development is not detrimental to the landscape character of the adjoining Pittwater waterway, and as such Parks, Reserves and Foreshores raise no concerns with the development proposal.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Parks, Reserves and Foreshores Conditions:

#### **CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

##### **Protection of Trees Within Land Owned or Managed by Council**

Unless identified by the development consent, existing trees shall be protected in accordance with AS4970- 2009 Protection of Trees on Development Sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor canopy disturbance.

Should any problems arise with regard to the existing trees on public land during the construction period, the applicant is to immediately contact Council's Tree Services section and resolve the matter to Council's satisfaction.

Reason: Tree protection and management.

## CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

### **No Access Through Land Owned or Managed by Council**

Site access is not approved for delivery of materials nor construction of the development through adjacent land owned or managed by Council, without the written approval of Council.

Reason: Public safety, landscape amenity and tree protection.

### **Storage of Materials on Land Owned or Managed by Council Prohibited**

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

### **Protection of Council's Public Assets**

Any damage to Council's public assets shall be made good by the applicant, and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to, the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993.

Existing trees shall be protected in accordance with AS4970-2009 Protection of Trees on Development Sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor canopy disturbance.

Should any problems arise with regard to the existing trees on public land during the construction period, the applicant is to immediately contact Council's Tree Services section and resolve the matter to Council's satisfaction.

Reason: To protect and/or restore any damaged public asset.