

## Building Assessment Referral Response

<b>Application Number:</b>	DA2019/0868
<b>To:</b>	Penny Wood
<b>Land to be developed (Address):</b>	Lot 261 DP 4889 , 27 Ellery Parade SEAFORTH NSW 2092

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

### Recommended Building Assessment Conditions

#### CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

**Blank condition for prior to construction certificate - replace this heading with your condition heading**

#### Change of Building Class/Building Upgrade

The existing building is proposed to be converted to a secondary dwelling will result in a change of classification to a Class 2 building and will be required to be upgraded to comply with Parts C, D, E & F (specifically sound transmission ratings) of the Building Code of Australia.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

**Reason:** To ensure adequate provision is made for fire safety and for building occupant safety