

# Natural Environment Referral Response - Riparian

Application Number:	DA2025/0485
Proposed Development:	Construction of a dwelling house
Date:	21/05/2025
То:	Olivia Ramage
Land to be developed (Address):	Lot 14 DP 271326 , 14 Raven Circuit WARRIEWOOD NSW 2102

#### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

## Officer comments

This application was assessed in consideration of:

- Coastal Management Act 2016;
- Supplied plans and reports;
- Warriewood Valley Urban Land Release Water Management Specification 2001; and
- Relevant LEP and DCP clauses.

The proposal is for a two-storey single dwelling. The area of the Lot is approx. 219.6m<sup>2</sup> (DP271326). A 5092L OSD / rainwater tank is proposed to be installed. The land is currently vacant. A detailed Soil Erosion and Sediment Control Plan is prepared as part of the DA package.

On internal assessment, it is determined that the proposed development satisfies the requirements of the DCP. No objections provided appropriate environmental protection controls are implemented during construction.

The proposal is therefore supported.

DA2025/0485 Page 1 of 3



Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

## **Recommended Natural Environment Conditions:**

# CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

## **Erosion and Sediment Control Plan**

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities)
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls that must include sediment fences, stabilised site access, materials and waste stockpiles locations, location of any stormwater pits on the site and how they are going to be protected.
- North point and scale.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval prior to the issue of the Construction Certificate.

Reason: To protect the receiving environment.

# CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

## Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prepared by FJA Designs prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: To protect the receiving environment.

# ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

#### **Maintenance of Stormwater Treatment Measures**

Stormwater treatment measures must be maintained at all times in accordance with manufacturer's

DA2025/0485 Page 2 of 3



specifications and as necessary to achieve the required stormwater quality targets for the development.

Northern Beaches Council reserves the right to enter the property and carry out appropriate maintenance of the device at the cost of the property owner.

Reason: To protect the receiving environment.

DA2025/0485 Page 3 of 3