

Natural Environment Referral Response - Coastal

Application Number:	DA2021/1408
Date:	01/03/2022
Responsible Officer	Maxwell Duncan
Land to be developed (Address):	Lot 2 DP 325220 , 16 Addison Road MANLY NSW 2095 Lot LIC 30003605 , 16 Addison Road MANLY NSW 2095

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

1/3/2022

In reviewing the coastal assessment, it is noted the proposed boatshed is above the mean high water mark and therefore outside W2 - Environmental Protection area.

Given that the proposed boatshed is above the mean high water mark, the boatshed is permissible under Clause 16 of the Sydney Harbour REP below. Consideration should be given if the boatshed is permissible under the Manly LEP and DCP.

The application is therefore supported.

In undertaking a coastal assessment, Council has considered:

- * Supplied plans and reports
- * Sydney Harbour REP (Sydney Harbour Catchment) and DCP
- * Manly LEP and DCP

Under the Sydney Regional Environmental Plan (Sydney Harbour Catchment) 2005, the proposed development is located in W2 - Environmental Protection. Under Clause 18 Development Control in the Waterways, boatsheds (private) are listed as a prohibited development.

The application is therefore not supported.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Stormwater Management

Stormwater shall be disposed of in accordance with Council's Policy. The stormwater management plan is to be implemented to ensure that there is no increase in stormwater pollutant loads arising from the approved development. Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from development, ensuring that the proposed works do not negatively impact receiving waters.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Stockpiling materials

During construction, all material associated with works is to be contained at source, covered and must be within the construction area. All material is to be removed off site and disposed of according to local regulations. The property is to be kept clean and any building debris removed as frequently as required to ensure no debris enters receiving waters.

Reason: To ensure pollution control measures are effective to protect the aquatic habitats within receiving waters throughout the construction period.

Pollution Control

All stockpiles, materials, waste and slurry associated with works (including excavated material) is to be contained at source within the construction area and enclosed in waterproof covering and/or sediment and erosion control while not in use. All waste/debris is to be removed off site and disposed of as frequently as required in accordance to local regulations.

Reason: To protect the surrounding environment, and ensure that pollutants and building associated waste do not leave the construction site.