

Engineering Referral Response

Application Number:	DA2020/1771
Date:	31/05/2021
To:	Jordan Davies
Land to be developed (Address):	Lot 6 DP 771621 , 1 / 0 Middleton Road CROMER NSW 2099

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The subject site is burdened by a Council drainage easement and pipeline which may be impacted as part of the proposed works. In this regard, the applicant is required to demonstrate compliance with Council's Water Management Policy Clause 6.1. This consists of accurately locating, confirming dimensions and plotting Council's stormwater pipelines and associated infrastructure to scale on the DA plans which show the proposed works. This should be carried out by a service locating contractor and registered surveyor. (The applicant will need to provide evidence of the methodology used for locating). A plan outlining the indicative locations of Council's stormwater infrastructure is available from Council's website. Northern Beaches Council has public stormwater drainage maps online. Please follow the relevant link below and select the 'Stormwater' map from the 'No Overlay Map' drop down menu. You can then search by address and use the zoom functionality to see pipe diameters and asset id numbers.

<https://services.northernbeaches.nsw.gov.au/icongis/index.html>

Development Engineers cannot support the application due to insufficient information to assess Clause C6 of Warringah DCP.

Additional information submitted 1/4/21

A review of the additional information indicates that the applicant has not accurately located the Council stormwater pipelines and associated infrastructure that traverses the site as requested previously. As such the applicant has not demonstrated that the proposal will not impact upon this infrastructure which is contrary to Council's Water Management Policy.

Development Engineers cannot support the application due to insufficient information to assess Clause C6 of Warringah DCP.

Additional Information submitted 12/05/2021

The submitted information does not accurately locate the Council stormwater infrastructure through the site as requested. The proposal to delay this information prior to CC is not supported. In order for the application to be supported, the proposed refueling structure must be deleted from the application.

Council's Traffic Engineer has provided conditions for the access to the site.

Subject to the deletion of the refueling structure, no objection to approval, subject to conditions as recommended.

Additional Information submitted 28/05/2021

The submitted survey plan and plans indicating the position of the Council stormwater pipeline through the site has been reviewed and accepted by Council's Stormwater Asset Engineer.

No objection to approval, subject to conditions as recommended.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

FEES / CHARGES / CONTRIBUTIONS

Construction, Excavation and Associated Works Bond (Drainage works)

The applicant is to lodge a bond of \$12,000 as security against any damage to Council's stormwater drainage infrastructure burdening the site as part of this consent.

Details confirming payment of the bond are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Protection of Council's infrastructure.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Structures Located Adjacent to Council Pipeline or Council Easement

All structures are to be located clear of any Council pipeline or easement. The Applicant is to ensure footings of any new development within this development consent adjacent to an easement or pipeline are to be designed in accordance with Northern Beaches Council's Water Management Policy.

Details and certification prepared by a suitably qualified Structural Engineer demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Protection of Council's infrastructure.

Structural Adequacy and Excavation Work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

Pre-Construction Stormwater Assets Dilapidation Report

The Applicant is to submit a pre-construction / demolition Dilapidation Survey of Council's Stormwater Assets is to be prepared by a suitably qualified person in accordance with Council's Guidelines for Preparing a Dilapidation Survey of Council Stormwater Asset, to record the existing condition of the asset prior to the commencement of works. Council's Guidelines are available at: <https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/general-information/engineering-specifications/2009084729guidelineforpreparingadilapidationsurveyofcouncilstormwaterassets2.pdf>

The pre-construction / demolition dilapidation report must be submitted to Council for approval and Council's written acceptance is to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Protection of Council's infrastructure.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Road Reserve

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

Certification of Structures Located Adjacent to Council Pipeline or Council Easement

The Applicant shall submit a suitably qualified Structural Engineer's certification that the completed footing works have been constructed in accordance with this consent, Northern Beaches Council's Water Management Policy and the approved Construction Certificate plans.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

Reason: Protection of Council's Infrastructure.

Post- Construction Stormwater Assets Dilapidation Report (Council stormwater assets)

The Applicant shall submit a post-construction Dilapidation Survey of Council's Stormwater Assets is to be prepared by a suitably qualified person in accordance with Council's Guidelines for Preparing a Dilapidation Survey of Council Stormwater Asset in order to determine if the asset has been damaged by the works. Council's Guidelines are available at <https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/general-information/engineering-specifications/preparingdilapidationsurveyforcouncilstormwaterassets.pdf>

The post-construction / demolition dilapidation report must be submitted to Council for review and approval. Any damage to Council's stormwater infrastructure is to be rectified prior to the release of any Drainage security bonds. Council's acceptance of the Dilapidation Survey is to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

Reason: Protection of Council's infrastructure.