



FIRE SAFETY SCHEDULE

*Prepared in accordance with clause 168 of the Environmental Planning & Assessment Regulation 2000
to accompany the subject Construction Certificate / Complying Development Certificate.*

Identification of building

Address: 2 Beach Rd, Palm Beach

Description of Work: Alterations to Existing Golf Club – Club House.

Fire Safety & Other Measures	Existing Measure	Proposed Measure	Modify Measure	Minimum Standards of Performance
Paths of Travel, stairways, passageways or ramps			✓	BCA Part D1.6, D2.19, D2.20
Fire Hose Reels	✓			BCA Cl. E1.4, AS 2441 - 2005
Emergency lighting			✓	BCA Part E4.2 & E4.4 AS 2293.1- 1995
Exit signs			✓	BCA Part E4.5 & E4.6 & E4.8 AS 2293.1- 1995
Portable fire extinguishers	✓			BCA Cl. E1.6 AS 2444 - 2001
Author	Kieran Tobin, BPB 0409			