

Engineering Referral Response

| | |
|--|--|
| Application Number: | Mod2018/0076 |
| To: | Rebecca Englund |
| Land to be developed (Address): | Lot 20 DP 632081 , 79 Cabbage Tree Road BAYVIEW NSW 2104 |

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

No objections to the proposed additional carparking spaces at grade and elevated subject to conditions.

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Engineering Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Stormwater Disposal

Stormwater shall be disposed of to an existing approved system or in accordance with Northern Beaches Council's PITTWATER DCP21, Details demonstrating that the existing approved system can accommodate the additional flows or compliance with the Council's specification are to be submitted to the Principal Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from

development.

Stormwater Disposal

Engineering Plans certified by an appropriately qualified and practicing Civil Engineer, indicating all details relevant to the collection and disposal of stormwater from the paved areas and where appropriate adjacent catchments. Details demonstrating compliance are to be submitted to the Principal Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from the development.

Geotechnical Report Recommendations have been correctly incorporated into designs and structural plans

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report prepared by Davies Geotechnical Consulting Engineers dated 29 January 2018 are to be incorporated into the construction plans.

Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier.

Reason: To ensure geotechnical risk is managed appropriately.

Elevated carparking bays construction

The elevated car parking bays are to be fully suspended off the natural ground levels. Structural engineering plans in accordance with the Davies Geotechnical Consulting Engineers report dated 29 January 2018 are to be submitted to the PCA prior to the issue of the construction certificate.

Reason: To minimize impacts on natural vegetation (DACENCPCC4)

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Civil Works Supervision

All civil works approved in the Construction Certificate are to be supervised by an appropriately qualified and practising Civil Engineer. Details demonstrating compliance are to be submitted to the Principal Certifying Authority

Reason: To ensure compliance of civil works with Council's specification for engineering works.

Maintenance of Sediment

Sedimentation and erosion controls are to be effectively maintained at all times during the course of construction and shall not be removed until the site has been stabilised or landscaped to the Principal Certifying Authority's satisfaction.

Reason: To ensure sediment controls are effective

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development

Geotechnical Certification Recommendations have been Implemented

Prior to issue of the Occupation Certificate, Form 3 of the Geotechnical Risk Management Policy (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier.

Reason: To ensure geotechnical risk is mitigated appropriately.