

Natural Environment Referral Response - Coastal

Application Number:	DA2020/0016
Responsible Officer	Julie Edwards
Land to be developed (Address):	Lot 10 DP 1207743 , 1110 Barrenjoey Road PALM BEACH NSW 2108

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Coastal Management) 2018

As the subject site has been identified as being within the coastal zone and therefore SEPP (Coastal Management) 2018 is also applicable to the proposed development. The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Clauses 13, 14 and 15 of the CM SEPP apply for this DA.

The DA satisfies requirements under clauses 13, 14 and 15 of the CM SEPP.

Pittwater LEP 2014 and Pittwater 21 DCP

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

Estuarine Risk Management

In accordance with the Pittwater Estuary Mapping of Sea Level Rise Impacts Study (2015), a base estuarine planning level (EPL) of RL2.8m AHD would apply at the subject site. A reduction factor (RF) based upon the distance from the foreshore of proposed development may also apply at a rate of 0.08m reduction to the EPL for every 5.00m distance from the foreshore edge up to a maximum distance of 40.00m.

Proposed development above the derived EPL

On internal assessment Council accepts the development is above the applicable EPL for the site.

The proposed development is therefore able to satisfy the relevant estuarine risk management

requirements of P21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site