

Landscape Referral Response

Application Number:	DA2020/0739
Date:	20/11/2020
Responsible Officer:	Lashta Haidari
Land to be developed (Address):	<p>Lot 13 DP 801798 , 62 May Road NARRAWEENA NSW 2099</p> <p>Lot 14 DP 801798 , 60 May Road NARRAWEENA NSW 2099</p> <p>Lot 15 DP 801798 , 58 May Road NARRAWEENA NSW 2099</p> <p>Lot 16 DP 801798 , 56 - 56 May Road NARRAWEENA NSW 2099</p> <p>Lot 17 DP 801798 , 54 - 54 May Road NARRAWEENA NSW 2099</p>

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The Arborist's Report and Landscape Plans provided with the application are noted.

The Arborist's Report recommends removal of 2 trees on the site due to health and structural issues. The trees, 1 x Lemon Scented Gum *Corymbia citriodora* and 1 x Jacaranda *Jacaranda mimosifolia* (an exempt species) have been rated as Low significance and High hazard rating. Whilst mature and providing significant canopy cover, the trees are not supported for retention the report due to their poor condition regardless of the proposed development.

The Landscape Plan indicates replanting of 6 trees and 8 palms/tree ferns within the development.

In consideration of the above, the proposal is considered to adequately the planning controls with regard to landscape issues.

Comments form Council's Parks and recreation section are noted, raising concerns with the location of the access stairs into the adjoining park and play equipment.

If this access was deleted, additional soft landscape could be incorporated by extending the planter over the location of the stairs.

No objections are raised to approval subject to conditions as recommended.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

(a) Existing trees which must be retained

- i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
- ii) Trees located on adjoining land

(b) Tree protection

- i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
- ii) All structures are to bridge tree roots greater than 50mm diameter unless directed otherwise by a qualified Arborist on site.
- iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
- iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
- v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE**

Landscape completion certification

- a) Prior to the issue of an Occupation Certificate, a landscape report prepared by a landscape architect or landscape designer shall be submitted to the Certifying Authority, certifying that the landscape works have been completed in accordance with the approved landscape plan and inclusive of any conditions of consent.
- b) Prior to the issue of an Occupation Certificate, a landscape report prepared by a landscape architect or landscape designer shall be submitted to the Certifying Authority, certifying that the landscape works have been established and maintained in accordance with the approved landscape plan.

Reason: To ensure that the landscape treatments are installed to provide landscape amenity.

Required Planting

- a) Trees, shrubs and groundcovers shall be planted in accordance with Landscape Plans Dwg Nos LP01, 02, 03 & 04 Rev A dated 26.03.20 prepared by Matthew Higginson Landscape Architecture:
- b) Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Landscape maintenance

- i) Trees shrubs and groundcovers required to be planted under this consent are to be mulched, watered and fertilized as required at the time of planting.
- ii) If any tree, shrub or groundcover required to be planted under this consent fails, they are to be replaced with similar species to maintain the landscape theme and be generally in accordance with the approved Landscape Plan.

Reason: To maintain local environmental amenity.