

16 September 2020

191134

Ascot Project Management  
Level 10, 420 George Street,  
Sydney 2000

Attention: Joanna Karamihas

**PROJECT MAUI ONCOLOGY, FRENCHS FOREST**  
**Zone of Influence of the Proposed Excavation**

---

Dear Joanna,

In response to Notice of Determination DA2019/1419 Conditions No. 23, we can confirm that the building works of the proposed development on Lot 7 only affects the buildings within the zone of influence of the excavation as shown on attached drawing.

The zone of influence of excavation is defined as a horizontal distance from the basement wall of twice the excavation depth as recommended in the JK Geotechnics geotechnical investigation report 32505BMrpt Rev 4, dated 17 February 2020. The structures and services that lie within the zone of influence would be subjected to dilapidation inspections, which are to be arranged by the main contractor.

Should you require anything further please contact the undersigned.

Yours faithfully,  
**TAYLOR THOMSON WHITTING (NSW) PTY LTD**  
in its capacity as trustee for the  
**TAYLOR THOMSON WHITTING NSW TRUST**



**DARREN JEFFREE**  
Technical Director

P:\2019\1911\191134\Letters\200916 Ltr Exavation Zone of Influence Statement\_MR.docx



## SITE PLAN

 ADJOINING BUILDINGS FALLS WITHIN EXCAVATION ZONE OF INFLUENCE THAT WOULD BE SUBJECTED TO DILAPIDATION INSPECTION. DILAPIDATION INSPECTION ARE TO BE ARRANGED BY THE MAIN CONTRACTOR