

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2020/0107
Date:	04/03/2020
To:	Thomas Prosser
Land to be developed (Address):	Lot 2 DP 16692 , 103 Narrabeen Park Parade MONA VALE NSW 2103

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The subject property abuts Warriewood Beach Reserve on its south eastern boundary. The topography of the site falls to the south east. To minimise potential erosion impacts on the reserve, sedimentation control has been conditioned.

No other issues with the proposal.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.