BASIX Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A353682

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

Secretarv Date of issue: Tuesday, 23, July 2019 To be valid, this certificate must be lodged within 3 months of the date of issue.



Project address	
Project name	Warren -BCC:PW
Street address	45 Carefree Road North Narrabeen 2101
Local Government Area	Northern Beaches Council
Plan type and number	Deposited Plan 11547
Lot number	25
Section number	
Project type	
Dwelling type	Separate dwelling house
Type of alteration and	My renovation work is valued at \$50,000 or mor and includes a pool (and/or spa).

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: BASIX Certificate Centre

ABN (if applicable): 31 430 367 846

Š

Pool and Spa	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Rainwater tank			
The applicant must install a rainwater tank of at least 1815 litres on the site. This rainwater tank must meet, and be installed in accordance with, the requirements of all applicable regulatory authorities.	~	×	\checkmark
The applicant must configure the rainwater tank to collect rainwater runoff from at least 100 square metres of roof area.		\checkmark	\checkmark
The applicant must connect the rainwater tank to a tap located within 10 metres of the edge of the pool.		\checkmark	\checkmark
Outdoor swimming pool			
The swimming pool must be outdoors.	\checkmark	~	\checkmark
The swimming pool must not have a capacity greater than 48 kilolitres.	\checkmark	\checkmark	\checkmark
The applicant must install a pool pump timer for the swimming pool.		\checkmark	\checkmark
The applicant must not incorporate any heating system for the swimming pool that is part of this development.		\checkmark	\checkmark

Fixtures and systems	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Hot water			
The applicant must install the following hot water system in the development: gas instantaneous.	\checkmark	\checkmark	\checkmark
Lighting			
The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps.		~	\checkmark
Fixtures			
The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating.		\checkmark	\checkmark
The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating.		\checkmark	\checkmark
The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating.		\checkmark	

Construction			Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Insulation requirements					
	l construction (floor(s), walls, and ceilings/roofs) tion is not required where the area of new constr where insulation already exists.		~	~	~
Construction	Additional insulation required (R-value)	Other specifications			
concrete slab on ground floor.	nil				
suspended floor with open subfloor: framed (R0.7).	R0.8 (down) (or R1.50 including construction)				
suspended floor with enclosed subfloor: framed (R0.7).	R0.60 (down) (or R1.30 including construction)				
floor above existing dwelling or building.	nil				
external wall: framed (weatherboard, fibro, metal clad)	R1.30 (or R1.70 including construction)				
external wall: other/undecided	R1.70 (including construction)				
raked ceiling, pitched/skillion roof: framed	ceiling: R2.26 (up), roof: foil/sarking	light (solar absorptance < 0.475)			
flat ceiling, flat roof: framed	ceiling: R2.32 (up), roof: foil/sarking	light (solar absorptance < 0.475)			

Glazing requirements	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Windows and glazed doors	1	l	
The applicant must install the windows, glazed doors and shading devices, in accordance with the specifications listed in the table below. Relevant overshadowing specifications must be satisfied for each window and glazed door.	~	~	~
The following requirements must also be satisfied in relation to each window and glazed door:		\checkmark	\checkmark
Each window or glazed door with standard aluminium or timber frames and single clear or toned glass may either match the description, or, have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions.		~	~
Each window or glazed door with improved frames, or pyrolytic low-e glass, or clear/air gap/clear glazing, or toned/air gap/clear glazing must have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions. The description is provided for information only. Alternative systems with complying U-value and SHGC may be substituted.		~	~
For projections described in millimetres, the leading edge of each eave, pergola, verandah, balcony or awning must be no more than 500 mm above the head of the window or glazed door and no more than 2400 mm above the sill.	~	~	~
For projections described as a ratio, the ratio of the projection from the wall to the height above the window or glazed door sill must be at least that shown in the table below.	\checkmark	~	~
Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35.		\checkmark	\checkmark
External louvres and blinds must fully shade the window or glazed door beside which they are situated when fully drawn or closed.		\checkmark	\checkmark
Pergolas with fixed battens must have battens parallel to the window or glazed door above which they are situated, unless the pergola also shades a perpendicular window. The spacing between battens must not be more than 50 mm.		~	~
Overshadowing buildings or vegetation must be of the height and distance from the centre and the base of the window and glazed door, as specified in the 'overshadowing' column in the table below.	~	~	~
Windows and glazed doors glazing requirements			

Glazing requirements							Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Window / door no.	Orientation	Area of glass inc. frame (m2)	Oversha Height (m)	adowing Distance (m)	Shading device	Frame and glass type			
W1	W	5	0	0	external louvre/blind (adjustable)	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W2	E	1.2	0	0	projection/height above sill ratio >=0.23	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W3	W	7	0	0	external louvre/blind (adjustable)	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W4	S	20	0	0	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W5	E	1.1	0	0	projection/height above sill ratio >=0.23	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W6	N	2	0	0	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W7	W	2.8	0	0	projection/height above sill ratio >=0.29	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W8	S	4.2	0	0	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W9	S	4.2	0	0	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W10	W	3.2	6.4	9.5	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W11	W	3.2	6.4	9.5	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W12	W	1.7	6.4	9.5	projection/height above sill ratio >=0.36	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W13	W	3	0	0	projection/height above sill ratio >=0.36	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			

Glazing requ	irements						Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Window / door no.	Orientation	Area of glass inc. frame (m2)	Oversha Height (m)	adowing Distance (m)	Shading device	Frame and glass type			
W14	E	8.7	0	0	external louvre/blind (adjustable)	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W15	E	1.7	0	0	projection/height above sill ratio >=0.36	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W16	E	3.2	0	0	projection/height above sill ratio >=0.36	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W17	E	3.2	0	0	projection/height above sill ratio >=0.36	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W18	E	2	0	0	projection/height above sill ratio >=0.36	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W19	W	3.1	0	0	projection/height above sill ratio >=0.36	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W20	E	8.7	0	0	external louvre/blind (adjustable)	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W21	E	1.7	0	0	projection/height above sill ratio >=0.36	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W22	E	3.2	1.4	3.5	projection/height above sill ratio >=0.36	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W23	E	3.2	1.4	3.5	projection/height above sill ratio >=0.36	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W24	E	2	0	0	projection/height above sill ratio >=0.36	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
W25 Bed	S	5.3	0	0	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
W26 Gym	S	5.3	0	0	eave/verandah/pergola/balcony >=900 mm	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			

Glazing requi	rements			Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Glazed roofs						
The applicant m	\checkmark	\checkmark	\checkmark			
The following requirements must also be satisfied in relation to each glazed roof:					\checkmark	\checkmark
Glazed roofs	s glazing requirer	nents				
Glazed roof number	Area of glazing (m2)	Shading device	Glass type			
Stairwell	14.14	no shading	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a " / " in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "
"
"
in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a " " in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.

Building Sustainability Index www.basix.nsw.gov.au