

Natural Environment Referral Response - Riparian

Application Number:	DA2019/1385
To:	Phil Lane
Land to be developed (Address):	Lot 14 DP 16998 , 10 Lincoln Avenue COLLAROY NSW 2097

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application has been assessed against:

State Environment Planning Policy (Coastal Management) 2018

Part 2, Division 3, Clause 13 - Development on land within the coastal environment area

Warringah Development Control Plan 2011

C4 - Stormwater

C5 - Erosion and Sedimentation

PL 850 Water - Water Management Policy

8 - Protecting Our Environment

As the development does not propose to significantly increase the impervious area of the site the applicant is not required to install a Stormwater Quality Improvement Device (SQID). The applicant must install sediment and erosion controls to prevent the migration of any sediment offsite. The sediment erosion controls must be installed prior to the commencement of works and are only to be removed once ground cover has been established.

With the application of sediment and erosion controls the proposal is unlikely to cause an adverse impact on the integrity and resilience of the biophysical, hydrological (surface and groundwater) and ecological environment.

Therefore this application is recommended for approval subject to conditions.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:**CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT****Installation and Maintenance of Sediment and Erosion Control**

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.