

## Building Assessment Referral Response

<b>Application Number:</b>	DA2023/1869
<b>Proposed Development:</b>	Demolition works and construction of a Residential Flat Building including the consolidation of 3 lots into 1
<b>Date:</b>	10/01/2024
<b>To:</b>	Gareth David
<b>Land to be developed (Address):</b>	Lot 5B DP 158658 , 58 Beaconsfield Street NEWPORT NSW 2106 Lot 6 DP 1096088 , 56 Beaconsfield Street NEWPORT NSW 2106 Lot 7B DP 162021 , 54 Beaconsfield Street NEWPORT NSW 2106

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

*Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.*

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

### **Building Code of Australia Fire Safety Requirements**

The Building Code of Australia fire safety requirements for the building as detailed and recommended in the da Stage BCA Report prepared by Steve Watson and Partners, dated 26/10/2023, Ref No, 2023/2093 including any required Performance Reviews, are to be considered as part of the assessment for any Construction Certificate. Details demonstrating compliance are to be provided to the Certifying Authority, prior to the issue of a Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

### **Access and Facilities for Persons with Disabilities**

Access and facilities to and within the building are to be provided as required for Persons with a Disability in accordance with the Building Code of Australia and AS1428. In this regard the Statement of Compliance – Access for People with Disabilities prepared by Accessible Building Solutions dated 10/11/2023 is to be taken into consideration as part of the assessment of the Construction Certificate. Details are to be provided to the Certifying Authority prior to the issue of the Construction Certificate and be implemented prior to occupation of the building.

Reason: To ensure adequate provision is made for access to and within the building for Persons with a disability.